

## Rejuvenation Product Approval Conditions

1. Develop a product specific Design and Installation Manual approved by the department.
2. Develop a checklist, approved by the department, to determine whether a rejuvenation product is suitable for installation at a site.
3. The owner or owner's agent must obtain a construction permit issued by the local health department (LHD) for the use of the product for repair of the on-site sewage system.
4. Installation shall be completed by a product manufacturer certified installer.
5. The property utilizing a residential or commercial on-site sewage system experiencing biomat formation failure in the soil absorption field may only be considered as a candidate for rejuvenation using the product if the LHD or IDOH has a complete construction permit on file for the site.
6. Start-up of the system and initial operation checks shall be conducted and documented by a product manufacturer certified professional.
7. The installation tank for the product must provide a minimum retention time of 48 hours of the system's daily design flow or meet or exceed current septic tank sizing requirements.
8. The product shall not be proposed for installations where:
  - a. The seasonal or perched water table, as identified in a soil evaluation report, would be less than twenty-four inches below the bottom of a subsurface soil absorption field or less than twenty inches below the bottom of an above-ground soil absorption field unless modified by subsurface drainage, or
  - b. The existing septic tank has not been inspected and shown to be watertight, or
  - c. The proposed installation is to precede a dry well, cesspool, or discharge tile.
9. The permittee shall maintain a service agreement with a manufacturer certified service provider throughout the lifetime of use of the product.
10. The product shall be inspected at a minimum of twice a year or more frequently to ensure the proper operation and maintenance of the product and soil absorption system.
11. A copy of the service contract must be submitted to the local health department prior to the issuance of the on-site sewage system permit for the product; and must be renewed at a minimum annually.

12. Submit a report to the TRP containing information on the product's use for the previous calendar year. The report is due by January 31 of the following year and shall include the following information:
  - a. Total number of units sold for use in Indiana, address and county of each install, owners name, owner's mailing address, type of use, and design flow, and
  - b. Date of installation and start up.