

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/31/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155143		(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 B. WING _____		(X3) DATE SURVEY COMPLETED 07/28/2015	
NAME OF PROVIDER OR SUPPLIER MEADOWS MANOR NORTH				STREET ADDRESS, CITY, STATE, ZIP CODE 3150 N SEVENTH ST TERRE HAUTE, IN 47804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS A Life Safety Code Preoccupancy Survey for the building addition and renovation of the former laundry area was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 07/28/15 Facility Number: 000067 Provider Number: 155143 AIM Number: 100267880 At this Life Safety Code survey, Meadows Manor North was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors, resident rooms and spaces open to the corridors. The facility has the capacity for 104 and had a census of 71 at the time of this survey. All areas accessible to residents and areas providing facility services were sprinklered.			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.