

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/21/2020
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001031	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MARION SURGICENTER B. WING _____		(X3) DATE SURVEY COMPLETED R 12/14/2020
NAME OF PROVIDER OR SUPPLIER MARION EYE SPECIALISTS SURGERY CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 711 W GARDNER DR MARION, IN 46952		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey on 11/02/20 was conducted by the Indiana State Department of Health in accordance with 42 CFR 416.44(b).</p> <p>Survey Date: 12/14/20</p> <p>Facility Number: 005975 Provider Number: 15C0001031 AIM Number: 200310700A</p> <p>At this PSR survey, Marion Eye Specialist Surgery Center was found in compliance with Requirements for Participation in Medicare/Medicaid 42 CFR Subpart 416.44 (b), Life Safety from Fire and the 2012 edition of the National Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies.</p> <p>This one story facility was determined to be of Type II (111) construction and was not sprinklered. The facility has a fire alarm system with smoke detection at the main fire alarm panel and in the duct work.</p> <p>Quality Review completed on 12/14/20</p>	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

12/18/2020

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.