

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

<b>STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS</b>		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: <b>15C0001015</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 0... B. WING	(X3) DATE SURVEY COMPLETED <b>04/03/2024</b>
NAME OF PROVIDER OR SUPPLIER <b>COMMUNITY SURGERY CENTER SOUTH</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>1550 E COUNTY LINE RD STE 100, INDIANAPOLIS, Indiana, 46227</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K0000 Bldg. 01	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 02/20/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 416.44(b).</p> <p>Survey Date: 04/03/24</p> <p>Facility Number: 005396</p> <p>Provider Number: 15C0001015</p> <p>AIM Number: 100274230A</p> <p>At this PSR survey, Community Surgery Center South was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies.</p> <p>This facility located on the first floor of a three story building consists of two attached sections due to the construction dates of the two sections of the building. Building 0101, built in 1986 was determined to be of Type II (000) construction and was fully sprinklered. Building 0202, built in 2005 was determined to be of Type II (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors.</p> <p>Quality Review completed on 04/03/24</p>	K0000			

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See reverse for further instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------