

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001120	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - BLDG B. WING _____		(X3) DATE SURVEY COMPLETED R 03/28/2022
NAME OF PROVIDER OR SUPPLIER FRANCISCAN SURGERY CENTER LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 5255 E STOP 11 ROAD, SUITE 100 INDIANAPOLIS, IN 46237		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 02/07/22 was conducted by the Indiana Department of Health in accordance with 42 CFR 416.44(b).</p> <p>Survey Date: 03/28/22</p> <p>Facility Number: 003217 Provider Number: 15C0001120 AIM Number: 1184601098</p> <p>At this PSR survey, Franciscan Surgery Center LLC was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 416.44(b), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 21, Existing Ambulatory Health Care Occupancies.</p> <p>The facility, located on the first floor of a four story building, was determined to be of Type II (111) construction and was fully sprinklered. The facility expanded into the west smoke compartment on the first floor of the building across from the main entrance lobby to the building and across from the east smoke compartment of the surgery center in 2015. The facility has a fire alarm system with smoke detection in patient rooms.</p> <p>Quality Review completed on 04/07/22</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

04/19/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.