

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005053	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/12/2021
NAME OF PROVIDER OR SUPPLIER MEMORIAL HOSPITAL OF SOUTH BEND		STREET ADDRESS, CITY, STATE, ZIP CODE 615 N MICHIGAN ST SOUTH BEND, IN 46601		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005053</p> <p>Survey Date: 1/12/2021</p> <p>The following patient rooms at Memorial Hospital of South Bend were successfully verified as negative pressure: 9th floor - Intermediate Care Center - Rooms: 933, 935, 936, 938, 939, 940, 941 and 942. 11th floor - Medical Unit - Room: 1144.</p> <p>The following patient rooms failed to be successfully verified as negative pressure: 937.</p> <p>QA: 1/26/21</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE