

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005020	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/03/2020
NAME OF PROVIDER OR SUPPLIER PARKVIEW REGIONAL MEDICAL CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 11109 PARKVIEW PLAZA DRIVE FORT WAYNE, IN 46845		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005020</p> <p>Survey Date: 9/3/20</p> <p>The following patient rooms at Parkview Regional Medical Center (main campus) were successfully verified as negative pressure: 6138, 6139, 6140, 6142, 6143, 6144, 6145, 6146, 6148, 6162, 6163, 6164, 6165, 6166, 6167, 6168, 6169, 6170, 6171 and 6172.</p> <p>The following patient rooms at Parkview Randallia Hospital (offsite location) were successfully verified as negative pressure: 256, 257, 258, 259, 260, 261, 262, 264, 265, 266, 267, 268, 269, 270, 271, 274, 275, 276, 277, 278 and 279.</p> <p>The following patient rooms failed to be successfully verified as negative pressure: None.</p> <p>QA: 9/8/2020</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE