

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005109	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/07/2021
NAME OF PROVIDER OR SUPPLIER COMMUNITY HOSPITAL SOUTH		STREET ADDRESS, CITY, STATE, ZIP CODE 1402 E COUNTY LINE RD S INDIANAPOLIS, IN 46227		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005109</p> <p>Survey Date: 9/7/2021</p> <p>The following patient rooms were successfully verified as negative pressure: 2108, 2109, 2110, 2111, 2112, 2113, 2114, 2115, 2116, 2117, 2118, 3104, 3105, 3106, 3107, 3108, 3109, 3110, 3111, 3114, 3115, 3116, 3117, 5101, 5102, 5103, 5104, 5105, 5106, 5108, 5109, 5110, 5111, 5112, 5113, 5114, 5115, 5116, 5117, and 5118.</p> <p>The following patient rooms failed to be successfully verified as negative pressure: None.</p> <p>QA: 9/13/2021</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE