

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/08/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 154011	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - BLDG B. WING _____		(X3) DATE SURVEY COMPLETED R 08/01/2022
NAME OF PROVIDER OR SUPPLIER COMMUNITY MENTAL HEALTH CENTER INC			STREET ADDRESS, CITY, STATE, ZIP CODE 285 BIELBY RD LAWRENCEBURG, IN 47025		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey was conducted on 06/21/22 was conducted by the Indiana Department of Health in accordance with 42 CFR 482.41(b).</p> <p>Survey Date: 08/01/22</p> <p>Facility Number: 005176 Provider Number: 154011 AIM Number: 200147890A</p> <p>At this PSR survey, Community Mental Health Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 482.41(b), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies.</p> <p>The Community Mental Health Center was located on the non sprinklered first floor, East Wing, of a three story, partially sprinklered hospital with a basement of Type I (332) construction. There is a 2 hour fire separation wall between the hospital and the Community Mental Health Center. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and hard wired smoke detectors in all patient sleeping rooms. The facility has a capacity of 16 and had a census of 9 at the time of this survey.</p> <p>Quality Review completed on 08/03/22</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

08/05/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.