Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING:		(X3) DATE SURVEY COMPLETED	
		005075	B. WING		03/23/2020	
NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE						
ST VINCENT HOSPITAL & HEALTH SERVICES INDIANAPOLIS, IN 46260						
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTIC (EACH CORRECTIVE ACTION SHOULE CROSS-REFERENCED TO THE APPROP DEFICIENCY)	TION SHOULD BE COMPLETE THE APPROPRIATE DATE	
S 000	S 000 INITIAL COMMENTS		S 000			
	This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.					
	Facility Number: 005075					
	Survey Date: 3/23/2020					
	verified as negative p 2634, 2635, 2636, 26 2643, 2644, 2645, 26	rooms were successfully ressure: 37, 2638, 2639, 2640, 2642, 46, 2647, 7410, 7411, 7412, 26, 7427, 7428, 7429				
	The following patient rooms failed to be successfully verified as negative pressure: None					
	QA: 3/24/20					

Indiana State Department of Health
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE (X6) DATE