

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005099	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/13/2021
NAME OF PROVIDER OR SUPPLIER COLUMBUS REGIONAL HOSPITAL		STREET ADDRESS, CITY, STATE, ZIP CODE 2400 E 17TH ST COLUMBUS, IN 47201		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-02-HOSP.</p> <p>Facility Number: 005099</p> <p>Survey Date: 1/13/2021</p> <p>The following patient rooms/areas were successfully verified as converted from Intensive Care Unit (ICU) rooms to Catheter Laboratory rooms: CL1, CL2, CL3, CL4, CL5, CL6, CL7, CL8, and CL9.</p> <p>QA: 1/25/21</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE