

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>005007</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>02/18/2021</b>
NAME OF PROVIDER OR SUPPLIER  <b>COMMUNITY HOWARD REGIONAL HEALTH INC</b>		STREET ADDRESS, CITY, STATE, ZIP CODE  <b>3500 S LAFOUNTAIN ST KOKOMO, IN 46902</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005007</p> <p>Survey Date: 2-18-2021</p> <p>The following patient rooms were successfully verified as negative pressure: Medical/Surgical rooms 202, 203, 204, 205, 206, 207, 208, 209, 210, 250 and 252 and Short Stay rooms 102, 104, 106 and 110 and Emergency Department room 1.</p> <p>The following patient rooms failed to be successfully verified as negative pressure: Short Stay room 108 and Emergency Room 2.</p> <p>QA: 2/19/21</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE