

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005079	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/06/2020
NAME OF PROVIDER OR SUPPLIER INDIANA UNIVERSITY HEALTH BALL MEMORIAL HOSPITAL		STREET ADDRESS, CITY, STATE, ZIP CODE 2401 UNIVERSITY AVE MUNCIE, IN 47303		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005079</p> <p>Survey Date: 11-06-2020</p> <p>The following patient rooms were successfully verified as negative pressure by a visual monitoring mechanism indicating the air pressure status at all times: CIC room 2333, MTU room 4308 and MDU room 4330.</p> <p>The following (previously reported) patient rooms failed to be successfully verified as negative pressure: 3311</p> <p>QA: 11/13/20</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE