

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005023	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 04/06/2020
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ESKENAZI HEALTH	STREET ADDRESS, CITY, STATE, ZIP CODE 720 ESKENAZI AVENUE INDIANAPOLIS, IN 46202
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure patient rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 005023</p> <p>Survey Date: 4/6/2020</p> <p>The following patient rooms were successfully verified as negative pressure: 6th floor: H6-101, H6-103, H6-105, H6-109, H6-111, H6-104, H6-106, H6-108, H6-110, H6-112, H6-114, H6-303, H6-305, H6-307, H6-311, H6-313, H6-302, H6-304, H6-306, H6-308, H6-310, H6-312, H6-403, H6-405, H6-407, H6-411, H6-413, H6-412, H6-416, H6-418, H6-420, H6-422, H6-424.</p> <p>9th floor: H9-101, H9-103, H9-105, H9-109, H9-111, H9-104, H9-106, H9-108, H9-110, H9-112, H9-114, H9-203, H9-205, H9-207, H9-211, H9-213, H9-212, H9-214, H9-216, H9-218, H9-220, H9-222, H9-303, H9-305, H9-307, H9-311, H9-313, H9-302, H9-304, H9-306, H9-308, H9-310, H9-312, H9-403, H9-405, H9-407, H9-411, H9-413, H9-412, H9-416, H9-418, H9-420, H9-422, H9-424</p> <p>The rooms lacked a visual pressure monitoring mechanism indicating the air pressure status at all times of each individual room. The Building Management System (BMS) allows for activation of negative pressure and airflow monitoring in relation to corridors. "Neighborhoods" of 12 individual rooms that approximate units and halls are provided with 1 visual negative air pressure monitor as opposed to individual monitors for each room.</p>	S 000		

Indiana State Department of Health
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 005023	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 04/06/2020
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ESKENAZI HEALTH	STREET ADDRESS, CITY, STATE, ZIP CODE 720 ESKENAZI AVENUE INDIANAPOLIS, IN 46202
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	Continued From page 1 The following patient rooms failed to be successfully verified as negative pressure: None QA: 4/7/20	S 000		