

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 150045	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BLDG B. WING _____		(X3) DATE SURVEY COMPLETED R 10/02/2024
NAME OF PROVIDER OR SUPPLIER PARKVIEW DEKALB HOSPITAL			STREET ADDRESS, CITY, STATE, ZIP CODE 1316 E SEVENTH ST AUBURN, IN 46706		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted 11/16/23 through 11/17/23 and the PSR's on 01/22/24 and 08/26/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 482.41(b).</p> <p>Survey Date: 10/02/24</p> <p>Facility Number: 005041 Provider Number: 150045 AIM Number: 100269460A</p> <p>At this PSR survey, Parkview Dekalb Hospital was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 482.41(b), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code, Chapter 19 Existing Health Care occupancies.</p> <p>The facility is a three-story building. The original 1964 building and the 1976, 1992, 2001, and 2014 additions were determined to be Type I (332) construction and the 2008 and 2011 Emergency Department addition were determined to be Type II (222). The facility is fully sprinklered, has a monitored fire alarm system with smoke detection in the corridors and spaces open to the corridors and in the operating rooms. The facility is protected with a Type 1 EES by three generators. The facility does have a Category 1 Gas and Vacuum Piped Systems. The facility has a capacity of 57 with a census of 19.</p> <p>Quality Review completed on 10/03/24</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.