Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION (X3) A. BUILDING:			X3) DATE SURVEY COMPLETED	
			A. BOILDING.				
00497		004972	B. WING		04/09/2020		
NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE							
FRANCISCAN HEALTH INDIANAPOLIS INDIANAPOLIS, IN 46237							
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) (COM COM		
S 000	S 000 INITIAL COMMENTS		S 000				
	pressure patient room Program Advisory Let Number: AC-2020-01 Facility Number: 0049 Survey Date: 4/9/202 The following patient	tter -HOSP. 272 20 rooms were successfully					
	verified as negative pressure: T317, T431, T434, T454, T460, T461, T462, T463, W408. The following patient rooms failed to be						
	successfully verified a	as negative pressure: None.					

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE (X6) DATE