

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/23/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G448	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/19/2024
NAME OF PROVIDER OR SUPPLIER LOGAN COMMUNITY RESOURCES INC			STREET ADDRESS, CITY, STATE, ZIP CODE 907 COTTAGE GROVE AVENUE SOUTH BEND, IN 46616		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments A Post Survey Revisit (PSR) for the Emergency Preparedness Survey that exited on 05/16/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73 Survey Date: 07/19/24 Facility Number: 000962 Provider Number: 15G448 AIM Number: 100249360 At this Emergency Preparedness PSR, Logan Community Resources Inc was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475 The facility has 8 certified beds. All 7 beds are certified for Medicaid. At the time of the survey, the census was 7. Quality Review completed on 07/22/24	{E 000}			
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 05/16/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 07/19/24 Facility Number: 000962 Provider Number: 15G448 AIM Number: 100249360	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/23/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G448	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/19/2024
NAME OF PROVIDER OR SUPPLIER LOGAN COMMUNITY RESOURCES INC			STREET ADDRESS, CITY, STATE, ZIP CODE 907 COTTAGE GROVE AVENUE SOUTH BEND, IN 46616		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>At this Life Safety Code PSR, Logan Community Resources Inc was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This two story building with a partial basement was determined to be fully sprinklered. The facility has a monitored fire alarm system with hardwire smoke detection in corridors, in client sleeping rooms and all living areas. Heat detection was provided in the attic space. The facility has a capacity of 7 and had a census of 7 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 0.84.</p> <p>Quality Review completed on 07/22/24</p>	{K 000}			