

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- _____ B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.475.</p> <p>Survey Date: 02/24/2021</p> <p>Facility Number: 000816 Provider Number: 15G297 AIM Number: 100243710</p> <p>At this Emergency Preparedness survey, Adec, Inc., was found not in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475</p> <p>The facility has 8 certified beds. All 8 beds are certified for Medicaid. At the time of the survey, the census was 7.</p> <p>Quality Review completed on 02/25/21</p>	E 0000		
E 0039 Bldg. --	<p>403.748(d)(2), 416.54(d)(2), 418.113(d)(2), 441.184(d)(2), 482.15(d)(2), 483.475(d)(2), 483.73(d)(2), 484.102(d)(2), 485.625(d)(2), 485.68(d)(2), 485.727(d)(2), 485.920(d)(2), 486.360(d)(2), 491.12(d)(2), 494.62(d)(2)</p> <p>EP Testing Requirements</p> <p>*[For RNCHI at §403.748, ASCs at §416.54, HHAs at §484.102, CORFs at §485.68, OPO, "Organizations" under §485.727, CMHC at §485.920, RHC/FQHC at §491.12, ESRD Facilities at §494.62]:</p> <p>(2) Testing. The [facility] must conduct exercises to test the emergency plan annually. The [facility] must do all of the</p>			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>following:</p> <p>(i) Participate in a full-scale exercise that is community-based every 2 years; or</p> <p>(A) When a community-based exercise is not accessible, conduct a facility-based functional exercise every 2 years; or</p> <p>(B) If the [facility] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required community-based or individual, facility-based functional exercise following the onset of the actual event.</p> <p>(ii) Conduct an additional exercise at least every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed.</p> <p>*[For Hospices at 418.113(d):]</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- _____ B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>(2) Testing for hospices that provide care in the patient's home. The hospice must conduct exercises to test the emergency plan at least annually. The hospice must do the following:</p> <p>(i) Participate in a full-scale exercise that is community based every 2 years; or</p> <p>(A) When a community based exercise is not accessible, conduct an individual facility based functional exercise every 2 years; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospital is exempt from engaging in its next required full scale community-based exercise or individual facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d) (2) (i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(3) Testing for hospices that provide inpatient care directly. The hospice must conduct exercises to test the emergency plan twice</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

	<p>per year. The hospice must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual facility-based functional exercise; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospice is exempt from engaging in its next required full-scale community based or facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop led by a facilitator that includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the hospice's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the hospice's emergency plan, as needed.</p> <p>*[For PRFTs at §441.184(d), Hospitals at §482.15(d), CAHs at §485.625(d):] (2) Testing. The [PRTF, Hospital, CAH] must conduct exercises to test the emergency plan</p>			
--	--	--	--	--

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>twice per year. The [PRTF, Hospital, CAH] must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or</p> <p>(B) If the [PRTF, Hospital, CAH] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an [additional] annual exercise or and that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, a facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the [facility's] emergency plan, as needed.</p> <p>*[For LTC Facilities at §483.73(d):] (2) The [LTC facility] must conduct exercises</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures. The [LTC facility, ICF/IID] must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise.</p> <p>(B) If the [LTC facility] facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the LTC facility is exempt from engaging its next required a full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [LTC facility] facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [LTC facility] facility's emergency plan, as needed.</p>			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 02/24/2021
NAME OF PROVIDER OR SUPPLIER ADEC INC			STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>*[For ICF/IIDs at §483.475(d)]:</p> <p>(2) Testing. The ICF/IID must conduct exercises to test the emergency plan at least twice per year. The ICF/IID must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or.</p> <p>(B) If the ICF/IID experiences an actual natural or man-made emergency that requires activation of the emergency plan, the ICF/IID is exempt from engaging in its next required full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the ICF/IID's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the ICF/IID's emergency plan, as needed.</p>				

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 02/24/2021
NAME OF PROVIDER OR SUPPLIER ADEC INC			STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>*[For OPOs at §486.360]</p> <p>(d)(2) Testing. The OPO must conduct exercises to test the emergency plan. The OPO must do the following:</p> <p>(i) Conduct a paper-based, tabletop exercise or workshop at least annually. A tabletop exercise is led by a facilitator and includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. If the OPO experiences an actual natural or man-made emergency that requires activation of the emergency plan, the OPO is exempt from engaging in its next required testing exercise following the onset of the emergency event.</p> <p>(ii) Analyze the OPO's response to and maintain documentation of all tabletop exercises, and emergency events, and revise the [RNHCI's and OPO's] emergency plan, as needed.</p> <p>Based on record review and interview, the facility failed to conduct exercises to test the emergency plan at least twice per year. The ICF/IID facility must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>a. When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise.</p> <p>b. If the ICF/IID facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the ICF/IID facility is exempt from engaging its next required full-scale in a community-based or individual, facility-based full-scale functional exercise for 1 year following the onset of the actual event.</p>	E 0039	In March of 2020, ADEC Residential Vice President of Operations determined that the actual test of the emergency preparedness plan for 2020 would be the COVID-19 Public Health Emergency. On September 24, 2020, a tabletop exercise was completed testing a Public Health Emergency. ADEC Residential Vice President of Operations chose to use a Public Health Emergency as the focus of the tabletop due to being in the midst of quarantine in several homes, with multiple hospitalizations and an eventual three COVID-19	03/12/2021	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 02/24/2021
NAME OF PROVIDER OR SUPPLIER ADEC INC			STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>(ii) Conduct an additional exercise that may include, but is not limited to the following:</p> <p>a. A second full-scale exercise that is community-based or an individual, facility-based functional exercise.</p> <p>b. A mock disaster drill; or</p> <p>c. A tabletop exercise or workshop that is led by a facilitator that includes a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the ICF/IID facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the ICF/IID facility's emergency plan, as needed in accordance with 42 CFR 483.475(d)(2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>During record review with the Administrative Assistant on 02/24/2021 at 2:15 p.m., the facility provided documentation of testing for the emergency preparedness plan, however it was incomplete. The facility provided documentation of their response to the COVID-19 Public Health Emergency, and a Table-top Exercise regarding COVID-19, dated 09/24/2020. Based on interview at the time of record review, the Administrative Assistant agreed that the claimed actual event, and the subsequent Table-Top Exercise, were both on the COVID-19 PHE.</p> <p>This deficient finding was reviewed with the Administrative Assistant at the time of exit.</p>		<p>related deaths. This tabletop exercise assisted operational staff in focusing on and problem solving during the Public Health Emergency. The residential Vice President of Operations did not share the plans for testing the emergency preparedness plan with ADEC's Quality Assurance committee or ADEC's Safety committee.</p> <p>Annually, Residential Operations presents a summary of Department of Health and Life Safety survey findings, complaints and corrective actions to the board of directors. In addition, ADEC's Quality Assurance committee reviews survey findings and corrective actions.</p> <p>During the week of March 8, 2021, the acting Director of Residential Operations for all fourteen ADEC group homes will conduct a tabletop exercise pertaining to tornadic activity. ADEC is performing a tabletop Exercise, in compliance with the regulations, given the actual Public Health Emergency for covid-19 is still ongoing. The exercise will include the QIDPs and the acting Director of Residential Operations for all fourteen ADEC group homes. All identified problems with existing procedures and policies will be addressed. Relevant procedures and policies will be updated. All findings will be shared and</p>		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 02/24/2021</p> <p>Facility Number: 000816 Provider Number: 15G297 AIM Number: 100243710</p> <p>At this Life Safety Code survey, ADEC Inc. was found not in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>The one story facility with a basement was sprinklered. The facility has a fire alarm system</p>	K 0000	<p>affected staff trained.</p> <p>The monitoring procedure to ensure that the Plan of Correction is effective will be bi-annual reporting to the Safety committee (which meets monthly) and annually to the Quality Assurance Committee (which meets quarterly). At these updates, the Director of Residential Operations will identify the appropriate and required plans which will meet State Life Safety regulations. Person responsible: Director of Residential Operations</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S211 Bldg. 01	<p>with smoke detection on all levels including in the corridors, in sleeping rooms and in common living areas. The facility has a capacity of 8 and had a census of 7 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 3.7.</p> <p>Quality Review completed on 02/25/21</p> <p>NFPA 101 Means of Egress - General Means of Escape - General 2012 EXISTING Designated means of escape shall be continuously maintained clear of obstructions and impediments to full instant use in the case of fire or emergency. 33.2.2 Based on observation and interview, the facility failed to maintain 1 of 2 designated means of egress be continuously maintained clear of obstructions and impediments to full instant use in the case of fire or emergency. This deficient practice could affect one client needing to use the secondary means of egress.</p> <p>Findings include:</p> <p>During a facility tour with the Administrative Assistant on 02/24/2021 at 2:22 p.m. the secondary egress from FD's sleeping room was obstructed by a walker. Based on interview at the time of observation, the Administrative Assistant agreed that the door was obstructed. It was noted that this was corrected prior to the exit.</p> <p>This deficient finding was reviewed with the</p>	K S211	<p>The walker was moved from the egress on 02/24/21. Facility staff will be trained on the importance of keeping all egresses clear. The client was reminded that his walker cannot be placed in front of the door. In order to ensure compliance, QIDP and/or manager will perform random observations to be sure all egresses are clear. This will occur at least three times per week. Failure to comply will result in disciplinary action. Person responsible: QIDP, Group home manager</p>	03/08/2021

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 02/24/2021
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ADEC INC	STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S353 Bldg. 01	<p>Administrative Assistant at the time of exit.</p> <p>NFPA 101 Sprinkler System - Maintenance and Testing Sprinkler System - Maintenance and Testing 2012 EXISTING (Prompt) NFPA 13 and 13R Systems All sprinkler systems installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, and NFPA 13R, Standard for the Installation of Sprinkler Systems in Residential Occupancies Up To and Including Four Stories in Height, are inspected, tested and maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water Based Fire Protection System. NFPA 13D Systems Sprinkler systems installed in accordance with NFPA 13D, Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes, are inspected, tested and maintained in accordance with the following requirements of NFPA 25:</p> <ol style="list-style-type: none"> 1. Control valves inspected monthly (NFPA 25, section 13.3.2). 2. Gauges inspected monthly (NFPA 25, section 13.2.71). 3. Alarm devices inspected quarterly (NFPA 25, section 5.2.6). 4. Alarm devices tested semiannually (NFPA 25, section 5.3.3). 5. Valve supervisory switches tested semiannually (NFPA 25, section 13.3.3.5). 6. Visible sprinklers inspected annually ((NFPA 25, section 5.2.1). 7. Visible pipe inspected annually (NFPA 25, section 5.2.2). 8. Visible pipe hangers inspected annually 			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 02/24/2021
NAME OF PROVIDER OR SUPPLIER ADEC INC			STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>(NFPA 25, section 5.2.3). 9. Buildings inspected annually prior to freezing weather for adequate heat for water filled piping (NFPA 25, section 5.2.5). 10. A representative sample of fast response sprinklers are tested at 20 years (NFPA 25, section 5.3.1.1.1.2). 11. A representative sample of dry pendant sprinklers are tested at 10 years (NFPA 25, section 5.3.1.1.15). 12. Antifreeze solutions are tested annually (NFPA 25, section 5.3.4). 13. Control valves are operated through their full range and returned to normal annually (NFPA 25, section 13.3.3.1). 14. Operating stems of OS&Y valves are lubricated annually (NFPA 25, section 13.3.4). 15. Dry pipe systems extending into unheated portions of the building are inspected, tested and maintained (NFPA 25, section 13.4.4). A. Date sprinkler system last checked and necessary maintenance provided. _____ B. Show who provided the service. _____ C. Note the source of the water supply for the automatic sprinkler system. _____</p> <p>(Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system.) 33.2.3.5.3, 33.2.3.5.8, 9.7.5, 9.7.7, 9.7.8, and NFPA 25</p> <p>Based on record review and interview, the facility failed to maintain 1 of 1 sprinkler system in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, Section</p>	K S353	A service order was placed on 02/24/21 to have the antifreeze loop recharged. Going forward, the QIDP will review all VFP Fire system inspections to ensure that	03/08/2021	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G297	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____		X3) DATE SURVEY COMPLETED 02/24/2021
NAME OF PROVIDER OR SUPPLIER ADEC INC			STREET ADDRESS, CITY, STATE, ZIP CODE 1823 ASHLEY CT GOSHEN, IN 46526		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>5.3.4. Section 5.3.4 states that the freezing point of solutions in antifreeze shall be tested annually by measuring the specific gravity with a hydrometer or refractometer and adjusting the solution if necessary. This deficient practice affects all building occupants.</p> <p>Findings include:</p> <p>During record review with the Administrative Assistant on 02/24/2021 at 2:05 p.m. the Report of Inspection from the sprinkler vendor, dated 08/28/2020, indicated that the antifreeze measure at +5 degrees Fahrenheit. Based on interview at the time of record review, the Administrative Assistant agreed this was out of temperature range for the location of the facility.</p> <p>This deficient finding was reviewed with the Administrative Assistant at the time of exit.</p>		<p>any deficits are being addressed. Failure to comply may result in disciplinary action. Person responsible: QIDP</p>		