

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/12/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  15G134	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  R 05/08/2025
NAME OF PROVIDER OR SUPPLIER  ARC OPPORTUNITIES INC		STREET ADDRESS, CITY, STATE, ZIP CODE  0170 W 300 N HOWE, IN 46746		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{E 000}	<p>Initial Comments</p> <p>A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 02/20/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.475.</p> <p>Survey Date: 05/08/25</p> <p>Facility Number: 000671 Provider Number: 15G134 AIM Number: 100234320</p> <p>At this PSR survey, Arc Opportunities Inc was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475</p> <p>The facility has 6 certified beds. All 6 beds are certified for Medicaid. At the time of the survey, the census was 6.</p> <p>Quality Review completed on 05/09/25</p> <p>INITIAL COMMENTS</p>	{E 000}		
{K 000}	<p>A Post Survey Revisit (PSR) to the Life Safety Code Survey conducted on 02/20/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 05/08/25</p> <p>Facility Number: 000671 Provider Number: 15G134 AIM Number: 100234320</p> <p>At this PSR survey, ARC Opportunities Inc. was found in compliance with Requirements for</p>	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/12/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  15G134	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02  B. WING _____		(X3) DATE SURVEY COMPLETED  R 05/08/2025
NAME OF PROVIDER OR SUPPLIER  ARC OPPORTUNITIES INC		STREET ADDRESS, CITY, STATE, ZIP CODE  0170 W 300 N HOWE, IN 46746		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	<p>Continued From page 1</p> <p>Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one-story facility was fully sprinklered. The facility has a monitored fire alarm system with heat detection in the attic, smoke detection in the corridors, client sleeping rooms, and common living areas. Additionally, the facility has single station smoke alarms which are powered by electricity, not monitored, and not connected to the fire alarm system in the client's sleeping rooms and in the living room. The facility has a capacity of 6 and had a census of 6 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101, Alternative Approaches to Life Safety, Chapter 6, rated the facility slow with an E-Score of 2.3.</p> <p>Quality Review completed on 05/09/25</p>	{K 000}		