

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/13/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G563	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/07/2022
NAME OF PROVIDER OR SUPPLIER NEW HOPE OF INDIANA, INC			STREET ADDRESS, CITY, STATE, ZIP CODE 2999 WESTLANE RD INDIANAPOLIS, IN 46268	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 000	Initial Comments An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.475. Survey Date: 07/07/22 Facility Number: 001077 Provider Number: 15G563 AIM Number: 100245490 At this Emergency Preparedness survey, New Hope of Indiana Inc. was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475. The facility has 8 certified beds. All 8 beds are certified for Medicaid. At the time of the survey, the census was 8.	E 000		
K 000	Quality Review completed on 07/12/22 INITIAL COMMENTS A Life Safety Code Recertification Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 07/07/22 Facility Number: 001077 Provider Number: 15G563 AIM Number: 100245490 At this Life Safety Code survey, New Hope of Indiana, Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/13/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G563	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/07/2022
NAME OF PROVIDER OR SUPPLIER NEW HOPE OF INDIANA, INC		STREET ADDRESS, CITY, STATE, ZIP CODE 2999 WESTLANE RD INDIANAPOLIS, IN 46268		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1 and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story building was determined to be fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, sleeping rooms and all living areas. The facility has heat detection in the attic. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 1.8.</p> <p>Quality Review completed on 07/12/22</p>	K 000		