

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	X2) MULTIPLE CONSTRUCTION A. BUILDING <u>--</u> B. WING <u> </u>	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.475.</p> <p>Survey Date: 02/12/20</p> <p>Facility Number: 000775 Provider Number: 15G255 AIM Number: 100248960</p> <p>At this Emergency Preparedness survey, Res Care Community Alternatives Se In was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475.</p> <p>The facility has 8 certified beds. At the time of the survey, the census was 8.</p> <p>Quality Review completed on 02/20/20</p>	E 0000		
K 0000 Bldg. 02	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 02/12/20</p> <p>Facility Number: 000775 Provider Number: 15G255 AIM Number: 100248960</p> <p>At this Life Safety Code survey, Res Care Community Alternatives Se In was found not in</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S100 Bldg. 02	<p>compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility with a crawl space was fully sprinkled. This facility has a fire alarm system with hard wired smoke detection in the corridors, common living areas, and all client sleeping rooms. The facility has a capacity of 8 and had a census of 8 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101, Alternative Approaches to Life Safety, Chapter 6, rated the facility Slow with an E-Score of 3.72.</p> <p>Quality Review completed on 02/20/20</p> <p>NFPA 101 General Requirements - Other General Requirements - Other 2012 EXISTING List in the REMARKS section any LSC Section 33.1 or 33.2 General Requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567.</p> <p>Based on observation and interview, the facility failed to ensure 3 of 3 interior emergency lights were tested, maintained, and the records of the testing maintained. LSC 33. 1.1.3 states the provisions of Chapter 4, General, shall apply. LSC 4.6.12.3 states existing life safety features obvious to the public, if not required by the Code, shall either be maintained or removed. LSC 7.9.3.1.1</p>	K S100	<p>K0100: General Requirements</p> <p>Corrective Action:</p> <ul style="list-style-type: none"> Area Supervisor was trained to complete monthly 30 second tests and 90 minute test annually on emergency lights and document on the Emergency Light form. 	03/06/2020

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>testing of required emergency lighting systems shall be permitted to be conducted as follows:</p> <p>(1) Functional testing shall be conducted monthly, with a minimum of 3 weeks and a maximum of 5 weeks between tests, for not less than 30 seconds.</p> <p>(2) The test interval shall be permitted to be extended beyond 30 days with approval of the authority having jurisdiction.</p> <p>(3) Functional testing shall be conducted annually for a minimum of 1 ½ hours if the emergency lighting is battery powered.</p> <p>(4) The emergency lighting equipment shall be fully operational for the duration of the test.</p> <p>(5) Written records of visual inspections and tests shall be kept by the owner for inspection for the authority having jurisdiction.</p> <p>This deficient practice could affect all occupants in the facility.</p> <p>Findings include:</p> <p>Based on observations on 02/12/20 between 1:45 p.m. and 3:00 p.m. during a tour of the facility with the Direct Support Professional (DSP) #2, the facility had three battery powered emergency light units. Based on record review between 1:45 p.m. and 3:00 p.m., there was no documentation to show the battery powered emergency lights were tested for 30 seconds monthly during the past 12 months, plus, there was no documentation available for an annual 90 minute test during the past 12 months. Based on interview at the time of record review and observations, DSP #2 said she was not aware of any documentation available to show a 30 second monthly test for the past 12 months, or an annual 90 minute test during the past 12 months.</p>		<p>(Attachment A)</p> <ul style="list-style-type: none"> Program Manager created a form for the Area Supervisor to test the emergency lights monthly for 30 seconds and yearly for 90 minutes. (Attachment B) Area Supervisor completes weekly check which includes checking the emergency lights monthly and annually. (Attachment C) <p>Monitoring of Corrective Action:</p> <ul style="list-style-type: none"> Program Manager will ensure the Area Supervisor has completed the weekly check to inspect the emergency lights. Area Supervisor will send monthly check of the emergency lights to the Program Manager for monitoring and to ensure completion. Program Manager will contact Aramark for all issues with the emergency lights. <p>Completion Date: 3/6/20</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S345 Bldg. 02	<p>NFPA 101</p> <p>Fire Alarm System - Testing and Maintenance</p> <p>Fire Alarm System - Testing and Maintenance</p> <p>2012 EXISTING (Prompt)</p> <p>A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code.</p> <p>Records of system acceptance, maintenance and testing are readily available.</p> <p>9.7.5, 9.7.7, 9.7.8, and NFPA 25</p> <p>1. Based on record review and interview, the facility failed to ensure 1 of 1 fire alarm system was maintained in accordance with 9.6.1.3. LSC 9.6.1.3 requires a fire alarm system to be installed, tested, and maintained in accordance with NFPA 70, National Electrical Code and NFPA 72, National Fire Alarm Code. NFPA 72, 7-3.2 requires testing shall be performed in accordance with the Table 14.4.5 Testing Frequencies. This deficient practice could affect all occupants in the facility.</p> <p>Findings include:</p> <p>Based on record review on 02/12/20 between 1:45 p.m. and 3:00 p.m. with the Direct Support Professional (DSP) #2 present, there was no documentation for an annual fire alarm system test/inspection during the past 12 months available for review other than the tag on the fire alarm control panel dated 10/26/19. Based on interview at the time of record review, DSP #2 was unable to produce documentation for an annual fire alarm system test/inspection during the past 12 months.</p> <p>2. Based on record review and interview, the</p>	K S345	<p>K0345: Testing and Maintenance</p> <p>Corrective Action:</p> <ul style="list-style-type: none"> Program Manager contacted Aramark to have documents of fire system inspections sent to Rescare to have them placed in the facility. Program Manager received documentation of the annual inspection including sensitivity testing that was completed on 10/26/19 (Attachment D) Program Manager will follow up with Aramark to ensure all documents are received as completed and all inspections are completed as scheduled. <p>Monitoring of Corrective Action:</p> <ul style="list-style-type: none"> Office Coordinator has set up with Aramark that all scheduling be done through our main office and all documents of inspections 	03/06/2020

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/12/2020

FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020	
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN			STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>facility failed to maintain 1 of 1 fire alarm systems in accordance with NFPA 72, as required by LSC 101 Section 9.6. NFPA 72, Section 14.3.1 states that unless otherwise permitted by 14.3.2, visual inspections shall be performed in accordance with the schedules in Table 14.3.1, or more often if required by the authority having jurisdiction. Table 14.3.1 states that the following must be visually inspected semi-annually:</p> <ul style="list-style-type: none"> a. Control unit trouble signals b. Remote annunciators c. Initiating devices (e.g. duct detectors, manual fire alarm boxes, heat detectors, smoke detectors, etc.) d. Notification appliances e. Magnetic hold-open devices <p>This deficient practice could affect all occupants in the facility.</p> <p>Findings include:</p> <p>Based on record review on 02/12/20 between 1:45 p.m. and 3:00 p.m. with the Direct Support Professional (DSP) #2 present, no documentation could be provided regarding a visual semi-annual fire alarm system inspection during the past 12 months, furthermore, there was no documentation of an annual fire alarm system inspection during the past 12 months other than the tag on the fire alarm control panel dated 10/26/19. Based on interview at the time of record review, DSP #2 was unable to produce documentation for a semi-annual visual fire alarm system test/inspection during the past 12 months.</p> <p>3. Based on record review and interview, the facility failed to ensure 1 of 1 fire alarm systems was maintained in accordance with 9.6.1.3. LSC 9.6.1.3 requires a fire alarm system to be installed, tested, and maintained in accordance with NFPA</p>			<p>be emailed to the Program Managers to ensure the documentation is in the facility.</p> <ul style="list-style-type: none"> ·Program Director will follow up on issues noted on the Site review and submit to the Program Manager for follow up on the issues. <p>Completion Date: 3/6/20</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S353 Bldg. 02	<p>70, National Electrical Code and NFPA 72, National Fire Alarm Code. NFPA 72, 7-3.2 requires testing shall be performed in accordance with the Table 14.4.5 Testing Frequencies. NFPA 72, 14.4.5.3.1 states sensitivity shall be checked within 1 year after installation. NFPA 72, 14.4.5.3.2 states sensitivity shall be checked every alternate year thereafter unless otherwise permitted by compliance with 14.4.5.3.3. This deficient practice could affect all occupants in the facility.</p> <p>Findings include:</p> <p>Based on record review on 02/12/20 between 1:45 p.m. and 3:00 p.m. with the Direct Support Professional (DSP) #2 present, there was no documentation for a smoke detector sensitivity test was available for review. Based on interview at the time of record review, DSP #2 was unable to produce a smoke detector sensitivity test performed within the past 24 months.</p> <p>NFPA 101 Sprinkler System - Maintenance and Testing Sprinkler System - Maintenance and Testing 2012 EXISTING (Prompt) NFPA 13 and 13R Systems All sprinkler systems installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, and NFPA 13R, Standard for the Installation of Sprinkler Systems in Residential Occupancies Up To and Including Four Stories in Height, are inspected, tested and maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water Based Fire Protection System. NFPA 13D Systems Sprinkler systems installed in accordance with NFPA 13D, Standard for the Installation</p>			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes, are inspected, tested and maintained in accordance with the following requirements of NFPA 25:</p> <ol style="list-style-type: none"> 1. Control valves inspected monthly (NFPA 25, section 13.3.2). 2. Gauges inspected monthly (NFPA 25, section 13.2.71). 3. Alarm devices inspected quarterly (NFPA 25, section 5.2.6). 4. Alarm devices tested semiannually (NFPA 25, section 5.3.3). 5. Valve supervisory switches tested semiannually (NFPA 25, section 13.3.3.5). 6. Visible sprinklers inspected annually ((NFPA 25, section 5.2.1). 7. Visible pipe inspected annually (NFPA 25, section 5.2.2). 8. Visible pipe hangers inspected annually (NFPA 25, section 5.2.3). 9. Buildings inspected annually prior to freezing weather for adequate heat for water filled piping (NFPA 25, section 5.2.5). 10. A representative sample of fast response sprinklers are tested at 20 years (NFPA 25, section 5.3.1.1.1.2). 11. A representative sample of dry pendant sprinklers are tested at 10 years (NFPA 25, section 5.3.1.1.15). 12. Antifreeze solutions are tested annually (NFPA 25, section 5.3.4). 13. Control valves are operated through their full range and returned to normal annually (NFPA 25, section 13.3.3.1). 14. Operating stems of OS&Y valves are lubricated annually (NFPA 25, section 13.3.4). 15. Dry pipe systems extending into unheated portions of the building are 			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>inspected, tested and maintained (NFPA 25, section 13.4.4).</p> <p>A. Date sprinkler system last checked and necessary maintenance provided.</p> <p>B. Show who provided the service.</p> <p>C. Note the source of the water supply for the automatic sprinkler system.</p> <p>(Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system.)</p> <p>33.2.3.5.3, 33.2.3.5.8, 9.7.5, 9.7.7, 9.7.8, and NFPA 25</p> <p>1. Based on record review and interview, the facility failed to ensure there was documentation the sprinkler system was tested/inspected during 4 of the past 4 quarters in accordance with NFPA 25. NFPA 25, Section 5.2.5 states, waterflow alarm and supervisory alarm devices shall be inspected quarterly to verify that they are free of physical damage. An inspection is defined as a visual examination of a system or a portion thereof to verify that it appears to be in operating condition and is free of physical damage. Section 5.3.3.2 states vane-type and pressure switch-type water flow alarm devices shall be tested semiannually. A test is defined as a procedure used to determine the operational status of a component or system by conducting periodic physical checks, such as waterflow tests, fire pump tests, alarm tests, and trip tests of dry pipe, deluge, or preaction valves. This deficient practice could affect all clients and staff in the facility.</p> <p>Findings include:</p> <p>Based on record review on 02/12/20 between 1:45 p.m. and 3:00 p.m., with the Direct Support</p>	K S353	<p>K0353: Sprinkler System – Maintenance and Testing</p> <p>Corrective action:</p> <ul style="list-style-type: none"> · Program Manager contacted Aramark to have documents of Sprinkler system inspections sent to Rescare to have them placed in the facility. · Program Manager received documentation of the annual inspection including sensitivity testing that was completed on 10/29/19. (Attachment E) · Aramark technician completes monthly inspections on the sprinkler system. (Attachment F) · Program Manager will follow up with Aramark to ensure all documents are received as completed and all inspections are completed as scheduled. 	03/06/2020

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020	
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN			STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>Professional (DSP) #2 there were no quarterly sprinkler inspections available for the past 12 months to review. Based on interview at the time of record review, the DSP #2 was unable to produce documentation of quarterly sprinkler inspections for the past four quarters.</p> <p>2. Based on record review and interview, the facility failed to provide documentation of monthly sprinkler system inspections in accordance with NFPA 25. NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2011 Edition, Section 5.2.4.1 states gauges on wet pipe sprinkler systems shall be inspected monthly to ensure that they are in good condition and that normal water supply pressure is being maintained. Section 5.1.2 states valves and fire department connections shall be inspected, tested, and maintained in accordance with Chapter 13. Section 13.3.2.1.1 states valves secured with locks or supervised in accordance with applicable NFPA standards shall be permitted to be inspected monthly. Section 3.3.18 states an inspection is defined as a visual examination of a system or a portion thereof to verify that it appears to be in operating condition and is free of physical damage. This deficient practice could affect all clients and staff in the facility.</p> <p>Findings include:</p> <p>Based on record review on 02/12/20 between 1:45 p.m. and 3:00 p.m. with the Direct Support Professional (DSP) #2 present, there was no documentation available to show the sprinkler gauge and sprinkler valve had been inspected on a monthly basis for the past 12 months. Based on interview at the time of record review, DSP #2 was unable to produce documentation of monthly</p>			<p>Monitoring of Corrective Action:</p> <ul style="list-style-type: none"> Office Coordinator has set up with Aramark that all scheduling be done through our main office and all documents of inspections be emailed to the Program Managers to ensure the documentation is in the facility. Program Manager will follow-up with Residential Manager to ensure Aramark has completed the inspections and left documentation at the facility. <p>Completion Date: 3/6/20</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S712 Bldg. 02	<p>sprinkler gauge and sprinkler valve inspections.</p> <p>NFPA 101</p> <p>Fire Drills</p> <p>Fire Drills</p> <p>1. The facility must hold evacuation drills at least quarterly for each shift of personnel and under varied conditions to:</p> <ul style="list-style-type: none"> a. Ensure that all personnel on all shifts are trained to perform assigned tasks; b. Ensure that all personnel on all shifts are familiar with the use of the facility's emergency and disaster plans and procedures. <p>2. The facility must:</p> <ul style="list-style-type: none"> a. Actually evacuate clients during at least one drill each year on each shift; b. Make special provisions for the evacuation of clients with physical disabilities; c. File a report and evaluation on each drill; d. Investigate all problems with evacuation drills, including accidents and take corrective action; and e. During fire drills, clients may be evacuated to a safe area in facilities certified under the Health Care Occupancies Chapter of the Life Safety Code. <p>3. Facilities must meet the requirements of paragraphs (i) (1) and (2) of this section for any live-in and relief staff that they utilize.</p> <p>42 CFR 483.470(i)</p> <p>Based on record review and interview, the facility failed to ensure fire drills were held at varied times for 3 of 3 employee shifts during 4 of 4 quarters. This deficient practice could affect all clients in the facility.</p> <p>Findings include:</p>	K S712	<p>K0712: Fire Drills</p> <p>Corrective Action:</p> <ul style="list-style-type: none"> ·Area supervisor completed an inservice with the all staff over the drill schedule and proper times to conduct the drills including using varied times. (Attachment G) 	03/06/2020

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K S741 Bldg. 02	<p>Based on review of the facility's fire drills on 02/12/20 between 1:45 p.m. and 3:00 p.m. with the Direct Support Professional (DSP) #2 present, the following was noted:</p> <ul style="list-style-type: none"> a. Three of four, first shift (day) fire drills were performed between 7:45 a.m. and 8:00 a.m. b. Four of four, second shift (evening) fire drills were performed between 3:05 p.m. and 4:00 p.m. c. Four of four, third shift (night) fire drills were performed between 5:00 a.m. and 6:00 a.m. <p>During an interview at the time of record review, DSP #2 acknowledged the times of all three shifts fire drills were performed and agreed the times were not varied enough.</p>	K S741	<ul style="list-style-type: none"> · Site Supervisor will complete a weekly check to ensure drills are conducted as scheduled. (Attachment H) · Rescare Administration will complete monthly site reviews to ensure all drills are completed as scheduled. (Attachment I) <p>Monitoring of Corrective Action:</p> <ul style="list-style-type: none"> · The Area Supervisor will conduct a weekly check to ensure scheduled completions of the drills and send to the Program Manager. · The Safety Committee will monitor quarterly for completion of scheduled drills. · Rescare Administration Site Reviews will be sent to the Program Director and Executive Director once completed. <p>Completion Date: 3/6/20</p>	03/06/2020

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 15G255	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>02</u> B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2020
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN		STREET ADDRESS, CITY, STATE, ZIP COD 154 CHAD DR VERSAILLES, IN 47042		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>failed to ensure cigarette butts were properly disposed of at 1 of 2 areas where cigarettes were smoked. This deficient practice could affect all clients entering or exiting the front door area.</p> <p>Findings include:</p> <p>Based on observation on 02/12/20 between 1:45 p.m. and 3:00 p.m. during a tour of the facility with the Direct Support Professional (DSP) #2, there was an open metal bucket half full of cigarette butts on the front porch. This was acknowledged by DSP #2 at the time of observation.</p>		<p>Corrective Action:</p> <ul style="list-style-type: none"> Program Manager will inservice all staff that smoking can only occur where a noncombustible receptacle is located for disposal of cigarette butts. (Attachment J) Area Supervisor will inform all staff that they can only use the safety type ashtrays at the facility on the back area of the facility and not coffee cans or other non-safe containers monthly during staff meetings. <p>Monitoring of Corrective Action:</p> <ul style="list-style-type: none"> Area Supervisor will report to the Program Manager and Program Director if he locates a non-safe container that has been used for an ashtray at the facility. Area Supervisor will send the Program Manager all trainings or inservices completed on staff for proper disposal of their cigarette waste and monthly staff meetings. Site Reviews are completed monthly by Management staff to insure safety at the facility. Management staff will note the use of proper disposal of cigarette waste is being used. <p>Completion Date: 3/6/20</p>	