

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G442	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/24/2025
NAME OF PROVIDER OR SUPPLIER RES CARE COMMUNITY ALTERNATIVES SE IN			STREET ADDRESS, CITY, STATE, ZIP CODE 402 EWING LN JEFFERSONVILLE, IN 47130		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification Survey conducted on 03/04/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 04/24/25</p> <p>Facility Number: 000956 Provider Number: 15G442 AIM Number: 100244760</p> <p>At this PSR Life Safety Code survey, Res Care Community Alternatives SE IN was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story facility was determined to be fully sprinkled. The facility has a fire alarm system with hard wired smoke detection in the corridors, common living areas and all client sleeping rooms. The facility has a capacity of 8 and had a census of 6 at the time of this PSR survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 0.3.</p> <p>Quality Review completed on 05/01/25</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.