

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/25/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155469	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/23/2022
NAME OF PROVIDER OR SUPPLIER CASA OF HOBART			STREET ADDRESS, CITY, STATE, ZIP CODE 4410 W 49TH AVE HOBART, IN 46342	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Preoccupancy Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a) for a facility remodel conversion of dayroom 131 into a 6 bay room into a dialysis unit.</p> <p>Survey Date: 02/23/2022</p> <p>Facility Number: 000366 Provider Number: 155469 AIM Number: 100288900</p> <p>At this Life Safety Code and PreOccupancy survey, Casa of Hobart was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire, and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This facility was surveyed as three separate buildings due to the construction types of three sections of the building: Building 0102 originally built in 1951 as a house is of Type V (000) construction and is fully sprinklered; Building 0202 renovated in 1972 and 1999 was determined to be of Type II (111) construction and is now sprinklered; and Building 0302 built in 1999 was determined to be of Type V (111) construction and fully sprinklered, encompasses the north and southeast sections of the facility. The facility has one fire alarm system with smoke detection in the corridors and spaces open to the corridors. The facility has wired smoke detectors in all resident sleeping rooms. The facility has a capacity of 138 and a census of 87 at the time of</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/25/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155469	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/23/2022
NAME OF PROVIDER OR SUPPLIER CASA OF HOBART			STREET ADDRESS, CITY, STATE, ZIP CODE 4410 W 49TH AVE HOBART, IN 46342		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 this survey. All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered. Quality Review completed on 02/24/22	K 000			