

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/23/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/20/2023
NAME OF PROVIDER OR SUPPLIER GARDEN VILLA - BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 1100 S CURRY PK BLOOMINGTON, IN 47403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments A Post-Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 02/02/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 03/20/23 Facility Number: 000007 Provider Number: 155019 AIM Number: 100275040 At this PSR survey, Garden Villa-Bloomington was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 224 certified beds. At the time of the survey, the census was 84.	{E 000}			
{K 000}	Quality Review completed on 03/22/23 INITIAL COMMENTS A Post-Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 02/02/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 03/20/23 Facility Number: 000007 Provider Number: 155019 AIM Number: 100275040 At this PSR survey, Garden Villa-Bloomington was found in compliance with Requirements for	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/23/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155019	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/20/2023
NAME OF PROVIDER OR SUPPLIER GARDEN VILLA - BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 1100 S CURRY PK BLOOMINGTON, IN 47403		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has battery operated smoke detectors installed in resident sleeping rooms 101 through 126, 201 through 216 and 301 through 339. The facility has smoke detectors hard wired to the fire alarm system in resident sleeping rooms on Station 4, 5, and 6. The facility has a capacity of 224 and had a census of 84 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered except for two detached storage buildings.</p> <p>Quality Review completed on 03/22/23</p>	{K 000}			