

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/10/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155039	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/05/2022
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 317 BLAIR PIKE PERU, IN 46970		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/06/22 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 08/05/22 Facility Number: 000014 Provider Number: 155039 AIM Number: 100288670 At this PSR survey, Miller's Merry Manor was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire, and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type II (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors with battery powered smoke detectors in all resident sleeping rooms. The facility has a capacity of 130 and had a census of 47 at the time of this survey. All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered. Quality Review completed on 08/05/22	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.