

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 01/30/23</p> <p>Facility Number: 013293 Provider Number: 155827 AIM Number: 201273090</p> <p>At this Emergency Preparedness survey, Sage Bluff Health and Rehabilitation Center was found not in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has a capacity of 84 and had a census of 54 at the time of this survey.</p> <p>Quality Review completed on 02/02/23</p>			E 0000	/p>="" p="">		
E 0004 SS=C Bldg. --	<p>403.748(a), 416.54(a), 418.113(a), 441.184(a), 482.15(a), 483.475(a), 483.73(a), 484.102(a), 485.625(a), 485.68(a), 485.727(a), 485.920(a), 486.360(a), 491.12(a), 494.62(a)</p> <p>Develop EP Plan, Review and Update Annually</p> <p>§403.748(a), §416.54(a), §418.113(a), §441.184(a), §460.84(a), §482.15(a), §483.73(a), §483.475(a), §484.102(a), §485.68(a), §485.625(a), §485.727(a), §485.920(a), §486.360(a), §491.12(a), §494.62(a).</p> <p>The [facility] must comply with all applicable Federal, State and local emergency preparedness requirements. The [facility]</p>						

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Katie Robinson

Administrator

03/13/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>must develop establish and maintain a comprehensive emergency preparedness program that meets the requirements of this section. The emergency preparedness program must include, but not be limited to, the following elements:</p> <p>(a) Emergency Plan. The [facility] must develop and maintain an emergency preparedness plan that must be [reviewed], and updated at least every 2 years. The plan must do all of the following:</p> <p>* [For hospitals at §482.15 and CAHs at §485.625(a):] Emergency Plan. The [hospital or CAH] must comply with all applicable Federal, State, and local emergency preparedness requirements. The [hospital or CAH] must develop and maintain a comprehensive emergency preparedness program that meets the requirements of this section, utilizing an all-hazards approach.</p> <p>* [For LTC Facilities at §483.73(a):] Emergency Plan. The LTC facility must develop and maintain an emergency preparedness plan that must be reviewed, and updated at least annually.</p> <p>* [For ESRD Facilities at §494.62(a):] Emergency Plan. The ESRD facility must develop and maintain an emergency preparedness plan that must be [evaluated], and updated at least every 2 years.</p> <p>.</p> <p>Based on record review and interview, the facility failed to properly maintain the Emergency Preparedness Plan (EPP) in accordance with 42 CFR 483.73(a). This deficient practice could affect</p>			E 0004	1. The contact information in the EPP was updated to reflect the accurate and up-to-date contact information.		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0013 SS=C Bldg. --	<p>all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 10:41 a.m., the EEP located at the nurse's station had the staffing and contact information for their sister facility "Grey Stone." Based on an interview during records review, the Administrator and Environmental Services Director agreed the EEP located at the nurse's was not properly maintained and had information for another building.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>403.748(b), 416.54(b), 418.113(b), 441.184(b), 482.15(b), 483.475(b), 483.73(b), 484.102(b), 485.625(b), 485.68(b), 485.727(b), 485.920(b), 486.360(b), 491.12(b), 494.62(b)</p> <p>Development of EP Policies and Procedures §403.748(b), §416.54(b), §418.113(b), §441.184(b), §460.84(b), §482.15(b), §483.73(b), §483.475(b), §484.102(b), §485.68(b), §485.625(b), §485.727(b), §485.920(b), §486.360(b), §491.12(b), §494.62(b).</p> <p>(b) Policies and procedures. [Facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least every 2 years.</p>				<p>2. The entire EPP was reviewed and updated as needed to reflect current and accurate information.</p> <p>3. The Environmental Services Director was inserviced on the need to update the contact information on the EPP.</p> <p>4. The EPP will be audited monthly x 6 months to ensure that the information is current and accurate.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>*[For LTC facilities at §483.73(b):] Policies and procedures. The LTC facility must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.</p> <p>*Additional Requirements for PACE and ESRD Facilities:</p> <p>*[For PACE at §460.84(b):] Policies and procedures. The PACE organization must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must address management of medical and nonmedical emergencies, including, but not limited to: Fire; equipment, power, or water failure; care-related emergencies; and natural disasters likely to threaten the health or safety of the participants, staff, or the public. The policies and procedures must be reviewed and updated at least every 2 years.</p> <p>*[For ESRD Facilities at §494.62(b):] Policies and procedures. The dialysis facility must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least every 2 years. These emergencies include, but are not limited to, fire, equipment or power failures, care-related emergencies, water supply interruption, and natural disasters likely to occur in the facility's geographic area.</p> <p>Based on record review and interview, the facility failed to develop and implement emergency preparedness policies and procedures based on a facility-based and community-based risk assessment utilizing an all-hazards approach in accordance with 42 CFR 483.73(b). This deficient practice could affect all residents in the facility.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 10:31 a.m., the EPP did not have building specific Policies and Procedures identified by the facility-based and community-based risk assessment utilizing the all-hazards approach (i.e. tornado, winter storm, civil disturbance, active shooter). The EPP contained information on how to create each policy and the information that should be in each policy, but there was not information on the actual procedure for each policy or how to respond to an actual emergency in the facility. Based on interview at the time of record review, the Administrator agreed the EPP Policies and Procedures did not address how to respond to an actual emergency in the facility.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p>			E 0013	<p>1. The EPP quick response tools were updated to identify the steps to take during each type of emergency and the responsible party for each type of emergency.</p> <p>2. The EPP was reviewed and updated as needed to identify the appropriate responses to various emergencies.</p> <p>3. The Environmental Services Director was inserviced on the EPP plan.</p> <p>4. The EPP will be audited monthly x 6 months to ensure that no new policies are introduced that do not meet the standard.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0031 SS=C Bldg. --	<p>403.748(c)(2), 416.54(c)(2), 418.113(c)(2), 441.184(c)(2), 482.15(c)(2), 483.475(c)(2), 483.73(c)(2), 484.102(c)(2), 485.625(c)(2), 485.68(c)(2), 485.727(c)(2), 485.920(c)(2), 486.360(c)(2), 491.12(c)(2), 494.62(c)(2) Emergency Officials Contact Information §403.748(c)(2), §416.54(c)(2), §418.113(c)(2), §441.184(c)(2), §460.84(c)(2), §482.15(c)(2), §483.73(c)(2), §483.475(c)(2), §484.102(c)(2), §485.68(c)(2), §485.625(c)(2), §485.727(c)(2), §485.920(c)(2), §486.360(c)(2), §491.12(c)(2), §494.62(c)(2).</p> <p>[(c) The [facility] must develop and maintain an emergency preparedness communication plan that complies with Federal, State and local laws and must be reviewed and updated at least every 2 years [annually for LTC facilities]. The communication plan must include all of the following:</p> <p>(2) Contact information for the following: (i) Federal, State, tribal, regional, and local emergency preparedness staff. (ii) Other sources of assistance.</p> <p>*[For LTC Facilities at §483.73(c):] (2) Contact information for the following: (i) Federal, State, tribal, regional, and local emergency preparedness staff. (ii) The State Licensing and Certification Agency. (iii) The Office of the State Long-Term Care Ombudsman. (iv) Other sources of assistance.</p> <p>*[For ICF/IIDs at §483.475(c):] (2) Contact information for the following: (i) Federal, State, tribal, regional, and local emergency preparedness staff.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0039 SS=F Bldg. --	<p>(ii) Other sources of assistance. (iii) The State Licensing and Certification Agency. (iv) The State Protection and Advocacy Agency. Based on record review and interview, the facility failed to ensure the Emergency Preparedness Plan (EPP) communication plan included contact information for all the following: (i) Federal, State, tribal, regional, or local emergency preparedness staff (ii) The State Licensing and Certification Agency (iii) The Office of the State Long-Term Care Ombudsman (iv) Other sources of assistance in accordance with 42 CFR 483.73(c) (2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 11:02 a.m., the EPP communication plan was missing the contact information for The Office of the State Long-Term Care Ombudsman. Based on interview at the time of record review, the Maintenance Director agreed the EPP did not contain contact information for the State Ombudsman.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>403.748(d)(2), 416.54(d)(2), 418.113(d)(2), 441.184(d)(2), 482.15(d)(2), 483.475(d)(2), 483.73(d)(2), 484.102(d)(2), 485.625(d)(2), 485.68(d)(2), 485.727(d)(2), 485.920(d)(2), 486.360(d)(2), 491.12(d)(2), 494.62(d)(2) EP Testing Requirements §416.54(d)(2), §418.113(d)(2), §441.184(d)(2), §460.84(d)(2), §482.15(d)(2), §483.73(d)(2), §483.475(d)(2), §484.102(d)(2), §485.68(d)(2),</p>			E 0031	<p>1. The ombudsman's contact information was added to the EPP. 2. The entire EPP was reviewed and updated to ensure all necessary contact information for outside agencies was included. 3. The Environmental Services Director was inserviced on the need to include agency contact information in the EPP. 4. The EPP will be audited monthly x 6 months to ensure all required agency information is included in the EPP.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>§485.625(d)(2), §485.727(d)(2), §485.920(d)(2), §491.12(d)(2), §494.62(d)(2).</p> <p>*[For ASCs at §416.54, CORFs at §485.68, OPO, "Organizations" under §485.727, CMHCs at §485.920, RHCs/FQHCs at §491.12, and ESRD Facilities at §494.62]:</p> <p>(2) Testing. The [facility] must conduct exercises to test the emergency plan annually. The [facility] must do all of the following:</p> <p>(i) Participate in a full-scale exercise that is community-based every 2 years; or (A) When a community-based exercise is not accessible, conduct a facility-based functional exercise every 2 years; or (B) If the [facility] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required community-based or individual, facility-based functional exercise following the onset of the actual event.</p> <p>(ii) Conduct an additional exercise at least every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, facility-based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed.</p> <p>*[For Hospices at 418.113(d):]</p> <p>(2) Testing for hospices that provide care in the patient's home. The hospice must conduct exercises to test the emergency plan at least annually. The hospice must do the following:</p> <p>(i) Participate in a full-scale exercise that is community based every 2 years; or</p> <p>(A) When a community based exercise is not accessible, conduct an individual facility based functional exercise every 2 years; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospital is exempt from engaging in its next required full scale community-based exercise or individual facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>(3) Testing for hospices that provide inpatient care directly. The hospice must conduct exercises to test the emergency plan twice per year. The hospice must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual facility-based functional exercise; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospice is exempt from engaging in its next required full-scale community based or facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop led by a facilitator that includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the hospice's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the hospice's emergency plan, as needed.</p> <p>*[For PRFTs at §441.184(d), Hospitals at §482.15(d), CAHs at §485.625(d):]</p> <p>(2) Testing. The [PRTF, Hospital, CAH] must</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>conduct exercises to test the emergency plan twice per year. The [PRTF, Hospital, CAH] must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or</p> <p>(B) If the [PRTF, Hospital, CAH] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an [additional] annual exercise or and that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, a facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the [facility's] emergency plan, as needed.</p> <p>*[For PACE at §460.84(d):]</p> <p>(2) Testing. The PACE organization must conduct exercises to test the emergency plan at least annually. The PACE organization must do the following:</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE		
	<p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or</p> <p>(B) If the PACE experiences an actual natural or man-made emergency that requires activation of the emergency plan, the PACE is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the PACE's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the PACE's emergency plan, as needed.</p> <p>*[For LTC Facilities at §483.73(d):]</p> <p>(2) The [LTC facility] must conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures. The [LTC facility, ICF/IID] must do the following:</p> <p>(i) Participate in an annual full-scale exercise</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise.</p> <p>(B) If the [LTC facility] facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the LTC facility is exempt from engaging its next required a full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [LTC facility] facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [LTC facility] facility's emergency plan, as needed.</p> <p>*[For ICF/IIDs at §483.475(d)]:</p> <p>(2) Testing. The ICF/IID must conduct exercises to test the emergency plan at least twice per year. The ICF/IID must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual,</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>facility-based functional exercise; or.</p> <p>(B) If the ICF/IID experiences an actual natural or man-made emergency that requires activation of the emergency plan, the ICF/IID is exempt from engaging in its next required full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the ICF/IID's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the ICF/IID's emergency plan, as needed.</p> <p>*[For HHAs at §484.102]</p> <p>(d)(2) Testing. The HHA must conduct exercises to test the emergency plan at least annually. The HHA must do the following:</p> <p>(i) Participate in a full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise every 2 years; or.</p> <p>(B) If the HHA experiences an actual natural or man-made emergency that requires</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>activation of the emergency plan, the HHA is exempt from engaging in its next required full-scale community-based or individual, facility based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the HHA's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the HHA's emergency plan, as needed.</p> <p>*[For OPOs at §486.360]</p> <p>(d)(2) Testing. The OPO must conduct exercises to test the emergency plan. The OPO must do the following:</p> <p>(i) Conduct a paper-based, tabletop exercise or workshop at least annually. A tabletop exercise is led by a facilitator and includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. If the OPO experiences an actual natural or man-made emergency that requires activation of the emergency plan, the</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>OPO is exempt from engaging in its next required testing exercise following the onset of the emergency event.</p> <p>(ii) Analyze the OPO's response to and maintain documentation of all tabletop exercises, and emergency events, and revise the [RNHCI's and OPO's] emergency plan, as needed.</p> <p>*[RNCHIs at §403.748]:</p> <p>(d)(2) Testing. The RNHCI must conduct exercises to test the emergency plan. The RNHCI must do the following:</p> <p>(i) Conduct a paper-based, tabletop exercise at least annually. A tabletop exercise is a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(ii) Analyze the RNHCI's response to and maintain documentation of all tabletop exercises, and emergency events, and revise the RNHCI's emergency plan, as needed.</p> <p>Based on record review and interview, the facility failed to conduct an additional exercise of choice to test the emergency plan at least twice per year. The LTC facility must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>a. When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise.</p> <p>b. If the LTC facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the LTC facility is exempt from engaging its next required full-scale in a community-based or individual, facility-based full-scale functional exercise for 1 year following the onset of the actual event.</p>			E 0039	<p>1. An emergency event was recorded and an after action report was completed on 2/11/2023.</p> <p>2. The EPP was reviewed and updated to ensure that the EPP will be tested at least twice per year.</p> <p>3. The Environmental Services Director was inserved on the requirement for testing at least twice per year.</p> <p>4. The EPP will be audited monthly x 6 months to ensure adherence to requirements.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0041 SS=F Bldg. --	<p>(ii) Conduct an additional exercise that may include, but is not limited to the following:</p> <p>a. A second full-scale exercise that is community-based or an individual, facility-based functional exercise.</p> <p>b. A mock disaster drill; or</p> <p>c. A tabletop exercise or workshop that is led by a facilitator that includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the LTC facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the LTC facility's emergency plan, as needed in accordance with 42 CFR 483.73(d)(2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 9:54 a.m., there was an actual emergency in June of 2022, but documentation of an additional annual exercise of choice within the last year was not available for review. Based on interview at the time of records review, the Administrator stated an additional annual exercise of choice was not conducted within the last 12 months.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>482.15(e), 483.73(e), 485.625(e) Hospital CAH and LTC Emergency Power §482.15(e) Condition for Participation: (e) Emergency and standby power systems. The hospital must implement emergency and standby power systems based on the</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>emergency plan set forth in paragraph (a) of this section and in the policies and procedures plan set forth in paragraphs (b)(1)(i) and (ii) of this section.</p> <p>§483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility and the CAH] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section.</p> <p>§482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12-2, TIA 12-3, TIA 12-4, TIA 12-5, and TIA 12-6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4), and NFPA 110, when a new structure is built or when an existing structure or building is renovated.</p> <p>482.15(e)(2), §483.73(e)(2), §485.625(e)(2) Emergency generator inspection and testing. The [hospital, CAH and LTC facility] must implement the emergency power system inspection, testing, and [maintenance] requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code.</p> <p>482.15(e)(3), §483.73(e)(3), §485.625(e)(3) Emergency generator fuel. [Hospitals, CAHs and LTC facilities] that maintain an onsite fuel source to power emergency generators must have a plan for how it will keep emergency power systems operational during the</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE		
	<p>emergency, unless it evacuates.</p> <p>*[For hospitals at §482.15(h), LTC at §483.73(g), and CAHs §485.625(g):] The standards incorporated by reference in this section are approved for incorporation by reference by the Director of the Office of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. You may obtain the material from the sources listed below. You may inspect a copy at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. If any changes in this edition of the Code are incorporated by reference, CMS will publish a document in the Federal Register to announce the changes.</p> <p>(1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000.</p> <p>(i) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011.</p> <p>(ii) Technical interim amendment (TIA) 12-2 to NFPA 99, issued August 11, 2011.</p> <p>(iii) TIA 12-3 to NFPA 99, issued August 9, 2012.</p> <p>(iv) TIA 12-4 to NFPA 99, issued March 7, 2013.</p> <p>(v) TIA 12-5 to NFPA 99, issued August 1, 2013.</p> <p>(vi) TIA 12-6 to NFPA 99, issued March 3, 2014.</p> <p>(vii) NFPA 101, Life Safety Code, 2012</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>edition, issued August 11, 2011. (viii) TIA 12-1 to NFPA 101, issued August 11, 2011. (ix) TIA 12-2 to NFPA 101, issued October 30, 2012. (x) TIA 12-3 to NFPA 101, issued October 22, 2013. (xi) TIA 12-4 to NFPA 101, issued October 22, 2013. (xiii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009..</p> <p>Based on records review and interview, the facility failed to implement the emergency power system requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code in accordance with 42 CFR 483.73(e)(2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 10:11 a.m., the generator lacked monthly load testing and weekly inspection required by LSC and NFPA 110. Based on interview at the time of record review, the Environmental Services Director stated the generator was missing some of the required testing.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>A Life Safety Code (LSC) Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR</p>			E 0041	<p>1. Generator testing for the first half of 2022 could not be located. 2. Generator testing is currently being completed as required: monthly load testing and weekly inspection. 3. The Environmental Services Director was inserviced on the generator testing requirement. 4. The Generator testing will be audited monthly x 6 months to ensure adherence to requirements. Audits will be submitted to QAPI committee for review and further recommendations.</p>		03/01/2023
				K 0000	/p>="" p="">		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0222 SS=B Bldg. 01	<p>483.90(a).</p> <p>Survey Date: 01/30/23</p> <p>Facility Number: 013293 Provider Number: 155827 AIM Number: 201273090</p> <p>At this LSC survey, Sage Bluff Health and Rehabilitation Center was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety From Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, LSC, Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and hard wired smoke detectors in the resident rooms. The facility has a capacity of 84 and had a census of 54 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinkled. All areas providing facility services were sprinkled except a small storage shed.</p> <p>Quality Review completed on 02/02/23</p> <p>NFPA 101 Egress Doors Egress Doors Doors in a required means of egress shall not be equipped with a latch or a lock that requires the use of a tool or key from the egress side unless using one of the following special locking arrangements:</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE		
	<p>CLINICAL NEEDS OR SECURITY THREAT LOCKING</p> <p>Where special locking arrangements for the clinical security needs of the patient are used, only one locking device shall be permitted on each door and provisions shall be made for the rapid removal of occupants by: remote control of locks; keying of all locks or keys carried by staff at all times; or other such reliable means available to the staff at all times.</p> <p>18.2.2.2.5.1, 18.2.2.2.6, 19.2.2.2.5.1, 19.2.2.2.6</p> <p>SPECIAL NEEDS LOCKING ARRANGEMENTS</p> <p>Where special locking arrangements for the safety needs of the patient are used, all of the Clinical or Security Locking requirements are being met. In addition, the locks must be electrical locks that fail safely so as to release upon loss of power to the device; the building is protected by a supervised automatic sprinkler system and the locked space is protected by a complete smoke detection system (or is constantly monitored at an attended location within the locked space); and both the sprinkler and detection systems are arranged to unlock the doors upon activation.</p> <p>18.2.2.2.5.2, 19.2.2.2.5.2, TIA 12-4</p> <p>DELAYED-EGRESS LOCKING ARRANGEMENTS</p> <p>Approved, listed delayed-egress locking systems installed in accordance with 7.2.1.6.1 shall be permitted on door assemblies serving low and ordinary hazard contents in buildings protected throughout by an approved, supervised automatic fire detection system or an approved, supervised automatic sprinkler system.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
	<p>18.2.2.2.4, 19.2.2.2.4 ACCESS-CONTROLLED EGRESS LOCKING ARRANGEMENTS Access-Controlled Egress Door assemblies installed in accordance with 7.2.1.6.2 shall be permitted.</p> <p>18.2.2.2.4, 19.2.2.2.4 ELEVATOR LOBBY EXIT ACCESS LOCKING ARRANGEMENTS Elevator lobby exit access door locking in accordance with 7.2.1.6.3 shall be permitted on door assemblies in buildings protected throughout by an approved, supervised automatic fire detection system and an approved, supervised automatic sprinkler system.</p> <p>18.2.2.2.4, 19.2.2.2.4 Based on observation and interview, the facility failed to ensure the means of egress through 1 of 1 main entrance exit door was always readily accessible for residents without a clinical diagnosis requiring specialized security measures. Doors within a required means of egress shall not be equipped with a latch or lock that requires the use of a tool or key from the egress side unless otherwise permitted by LSC 19.2.2.2.4. Door-locking arrangements shall be permitted in accordance with 19.2.2.2.5.2. This deficient practice could affect over 15 residents, visitors, and staff.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 12:41 p.m., the main entrance was magnetically locked and equipped with a 15 second delayed egress with a backup access keypad with a posted code, but when the four-digit code was entered on the</p>		K 0222	<p>The code at the front door was immediately updated. The front door is the only exit affected by the deficient practice. The Environmental Services Director was inserviced on the requirement that codes on egress doors must be accurate. The front door code will be audited monthly x 6 months to ensure adherence to requirements. Audits will be submitted to QAPI committee for review and further recommendations.</p>		03/01/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0223 SS=E Bldg. 01	<p>access control pad the door would not open. Based on interview at the time of observation, the Environmental Services Director stated the code to open the exit door was incorrect.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Doors with Self-Closing Devices Doors with Self-Closing Devices Doors in an exit passageway, stairway enclosure, or horizontal exit, smoke barrier, or hazardous area enclosure are self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2 that automatically closes all such doors throughout the smoke compartment or entire facility upon activation of:</p> <ul style="list-style-type: none"> * Required manual fire alarm system; and * Local smoke detectors designed to detect smoke passing through the opening or a required smoke detection system; and * Automatic sprinkler system, if installed; and * Loss of power. <p>18.2.2.2.7, 18.2.2.2.8, 19.2.2.2.7, 19.2.2.2.8 Based on observation and interview, the facility failed to ensure 2 of 5 hazardous area enclosures were self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2. This deficient practice could affect 35 residents in two smoke compartments.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 12:49 p.m. and at 1:11 p.m., the medical records</p>			K 0223	<ol style="list-style-type: none"> 1. The doors in question were closed immediately. 2. All interior doors could be affected by the deficient practice. 3. All staff were inserviced regarding propping open doors that are equipped with automatic closures. 4. Self-closing doors will be audited weekly x 4 weeks and monthly x 5 months to ensure adherence to the requirement. 		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0227 SS=E Bldg. 01	<p>room and the central supply room contained over 20 boxes and supplies making the rooms hazardous areas. The doors to rooms were self-closing, but both doors were held open from the front with boxes and a door wedge. This condition does not allow the doors to automatically close upon activation of the fire alarm. Based on interview at the time of observation, the Environmental Services Director agreed the doors were held open with a device that did not release with the fire alarm and removed the door wedge and boxes.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Ramps and Other Exits Ramps and Other Exits Ramps, exit passageways, fire and slide escapes, alternating tread devices, and areas of refuge are in accordance with the provisions 7.2.5 through 7.2.12. 18.2.2.6 to 18.2.2.10 or 19.2.2.6 to 19.2.2.10 Based on observation and interview, the facility failed to ensure 1 of 1 exit discharge ramp was equipped with handrails. LSC Section 7.2.5.4.1 Guards complying with 7.2.2.4 shall be provided for ramps. This deficient practice could affect 25 residents evacuated from the 400-hall.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 2:01 p.m., the exit discharge from the 400-hall had a slope with a 35 feet long ramp. No handrails were provided for the ramp. Based on an interview at</p>			K 0227	<p>Audits will be submitted to QAPI committee for review and further recommendation.</p> <p>1. A vendor has been contacted to provide a quote to install a hand rail at the ramp located outside the 400 Hall egress door.</p> <p>2. No other exits are affected by the deficient practice.</p> <p>3. The Environmental Services Director was inserviced on the ramp requirements.</p> <p>4. The exit sidewalks will be audited monthly x 6 months to ensure adherence to the requirement. Audits will be</p>		04/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0321 SS=E Bldg. 01	<p>the time of observation, the Environmental Services Director agreed the egress exit sloped down and was not provided with handrails.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Hazardous Areas - Enclosure Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door.</p> <p>Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9</p> <p>Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons)</p>				submitted to QAPI committee for review and further recommendation.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0341 SS=E Bldg. 01	<p>f. Combustible Storage Rooms/Spaces (over 50 square feet)</p> <p>g. Laboratories (if classified as Severe Hazard - see K322)</p> <p>Based on observation and interview, the facility failed to ensure 2 of 2 storage rooms on the 200 hall were protected as hazardous areas. This deficient practice could affect 20 residents in 1 smoke compartments.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 2:30 p.m., storage rooms 210 and 211 contained large amounts of combustible boxes, supplies, combustible material and, was greater than 50 square feet making the rooms hazardous areas. The storage rooms were not protected as a hazardous area because the corridor doors to the rooms were not self-closing. Based on interview at the time of observation, the Administrator agreed the storage rooms contained large amounts of combustible storage, were larger than 50 square feet, and the corridor doors to the rooms were not self-closing.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Fire Alarm System - Installation Fire Alarm System - Installation A fire alarm system is installed with systems and components approved for the purpose in accordance with NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm Code to provide effective warning of fire in any</p>			K 0321	<p>1. Self-closing devices were installed on rooms 210 and 211.</p> <p>2. There are no other hazardous areas identified.</p> <p>3. The Environmental Services Director was inserviced about this requirement.</p> <p>4. Rooms throughout the facility will be audited monthly x 6 months to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>part of the building. In areas not continuously occupied, detection is installed at each fire alarm control unit. In new occupancy, detection is also installed at notification appliance circuit power extenders, and supervising station transmitting equipment. Fire alarm system wiring or other transmission paths are monitored for integrity.</p> <p>18.3.4.1, 19.3.4.1, 9.6, 9.6.1.8</p> <p>Based on observation and interview, the facility failed to ensure 1 of 1 fire alarm systems was installed in accordance with 19.3.4.1. LSC 9.6.1.3 requires a fire alarm system to be installed, tested, and maintained in accordance with NFPA 70, National Electrical Code and NFPA 72, National Fire Alarm Code. NFPA 72, 17.7.4.1 requires in spaces served by air handling systems, detectors shall not be located where air flow prevents operation of the detectors. This deficient practice could affect 25 residents in one smoke compartment.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 2:16 p.m.,</p> <p>On the drop ceiling in the corridor by the therapy door there was a smoke detector next to an air supply where air flow would prevent proper operation of the detector. The detector was a abut 18 inches from the vent. Based on interview at the time of observation, the Administrator agreed the smoke detector was in the direct airflow from the supply and was within 18 inches of the vent.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p>			K 0341	<p>1. The smoke detector in question was moved and is greater than 3 feet from the air source. All other smoke detectors could be at risk of this deficient practice. All smoke detectors reviewed to ensure they were not within the required distance from the air source.</p> <p>3. The Environmental Services Director was inserviced about this requirement.</p> <p>4. Smoke detectors will be audited monthly x 6 months to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0345 SS=F Bldg. 01	<p>3.1-19(b)</p> <p>NFPA 101 Fire Alarm System - Testing and Maintenance Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 #1) Based on record review and interview, the facility failed to maintain 1 of 1 fire alarm systems in accordance with NFPA 72, as required by LSC 101 Sections 19.3.4.5.1 and 9.6. NFPA 72, Section 14.3.1 states that unless otherwise permitted by 14.3.2, visual inspections shall be performed in accordance with the schedules in Table 14.3.1, or more often if required by the authority having jurisdiction. Table 14.3.1 states that the following must be visually inspected semi-annually:</p> <ul style="list-style-type: none"> a. Control unit trouble signals b. Remote annunciators c. Initiating devices (e.g. duct detectors, manual fire alarm boxes, heat detectors, smoke detectors, etc.) d. Notification appliances e. Magnetic hold-open devices <p>This deficient practice affects all occupants in the facility.</p> <p>Findings include:</p> <p>During records review with the Administrator and Environmental Services Director on 01/30/23 at 10:05 a.m., the fire alarm semi-annual fire alarm</p>			K 0345	<p>1. A Fire Alarm Annual assessment was conducted in September 2022 and January 2023 but documents were not available at the time of the survey. The time on the fire alarm panel was corrected immediately.</p> <p>2. No other areas identified.</p> <p>3. The Environmental Services Director was inserviced on both the assessment requirements and on the fire panel requirements.</p> <p>4. The Assessments and Fire Panel will be audited monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0346 SS=C	<p>inspection conducted in March of 2022 only listed the fire panel and batteries as inspected and did not list the control unit trouble signals, remote annunciators, initiating devices, notification appliances, and magnetic hold-open devices. Based on interview at the time of records review, the Environmental Services Director stated a visual inspection of all items on the fire alarm system six months prior to the annual fire alarm inspection was not properly conducted.</p> <p>#2) Based on observation and interview, the facility failed to ensure 1 of 1 fire alarm systems were in continuously proper operating condition. NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition, Section 14.2.1.2.2 states system defects and malfunctions shall be corrected. This deficient practice could affect all residents, staff and visitors.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 1:09 p.m., the time on the display of the fire alarm control panel indicated the time to be 2:28 p.m. when checked at 1:09 p.m. Based on interview at the time of observation, the Environmental Services Director agreed the fire alarm control panel had the wrong time and will need to be changed.</p> <p>The findings were reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Fire Alarm System - Out of Service</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
Bldg. 01	<p>Fire Alarm - Out of Service</p> <p>Where required fire alarm system is out of services for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service.</p> <p>9.6.1.6</p> <p>Based on record review and interview, the facility failed to provide a complete 1 of 1 written policy for the protection of residents indicating procedures to be followed in the event the fire alarm system has to be placed out of service for four hours or more in a twenty-four-hour period in accordance with LSC, Section 9.6.1.6. This deficient practice affects all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 12:13 a.m., the fire watch plan stated to contact the Department of Health but failed to include contacting the Indiana Department of Health via the IDOH Gateway link at https://gateway.isdh.in.gov as the primary method or by the secondary method when the IDOH Gateway is nonoperational by completing the Incident Reporting form and e-mailing it to incidents@isdh.in.gov. Also, the fire watch plan stated to contact the fire department, insurance carrier, facility operator, and mongering company but the space to list phone numbers was blank. Based on interview during the record review, the Administrator acknowledged the fire watch documentation provided stated to contact the department of health but not via the IDOH Gateway link or at the e-mail address listed above</p>			K 0346	<p>1. The Fire Policy was reviewed and revised to include all required information.</p> <p>2. No other areas of deficiency identified.</p> <p>3. The Environmental Services Director was inserviced about this requirement.</p> <p>4. The Fire Policy will be reviewed monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0352 SS=F Bldg. 01	<p>and the other contacts were left blank.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Sprinkler System - Supervisory Signals Sprinkler System - Supervisory Signals Automatic sprinkler system supervisory attachments are installed and monitored for integrity in accordance with NFPA 72, National Fire Alarm and Signaling Code, and provide a signal that sounds and is displayed at a continuously attended location or approved remote facility when sprinkler operation is impaired.</p> <p>9.7.2.1, NFPA 72 Based on observation and interview, the facility failed to maintain monitoring of 1 of 1 sprinkler system in accordance with LSC 9.7.2.1. LSC 19.3.5.1 states buildings containing nursing homes shall be protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 9.7. LSC 9.7.2.1 states where supervised automatic sprinkler systems are required by another section of this Code, supervisory attachments shall be installed and monitored for integrity in accordance with NFPA 72, National Fire Alarm and Signaling Code, and a distinctive supervisory signal shall be provided to indicate a condition that would impair the satisfactory operation of the sprinkler system. Supervisory signals shall sound and shall be displayed either at a location within the protected building that is constantly attended by qualified personnel or at an approved, remotely located receiving facility. This deficient practice could affect all residents</p>			K 0352	<p>1. The facility has contacted the vendor regarding the installation of electronic supervision for the automatic sprinkler system.</p> <p>2. No other areas of deficiency identified.</p> <p>3. The Environmental Services Director was inserviced about this requirement.</p> <p>4. The electronic supervision of the fire sprinkler system will be reviewed monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		04/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0353 SS=F Bldg. 01	<p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 1:10 p.m., in the riser room there were two (2) OS&Y control valves on the water main connecting to the sprinkler system. Both OS&Y valves were not electronically monitored by the building's fire alarm system. Based on interview at the time observation, the Environmental Services Director agreed the two OS&Y valves controlled water flow to the sprinkler system and were not electronically supervised.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Sprinkler System - Maintenance and Testing Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available.</p> <p>a) Date sprinkler system last checked</p> <p>b) Who provided system test</p> <p>c) Water system supply source</p> <p>Provide in REMARKS information on coverage for any non-required or partial</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
	<p>automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25</p> <p>Based on record review and interview, the facility failed to maintain 1 of 1 sprinkler system in accordance with LSC 9.7.5 which requires all automatic sprinkler systems shall be inspected and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. NFPA 25, 2011 edition, Table 5.1.1.2 indicates the required frequency of inspection and testing. This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 between 9:41 a.m. and 12:10 p.m., the following items were missing documentation of inspections:</p> <ul style="list-style-type: none"> a) Weekly visual inspection of the dry sprinkler system's pressure gauges. b) Monthly visual inspection of the wet sprinkler system's pressure gauges. c) Monthly visual inspection of the sprinkler system's control values. d) 3-year dry system trip test. e) 3-year dry system air leakage test. <p>During an interview at the time of record review, the Administrator and Environmental Services Director stated the aforementioned inspections were not completed or could not provide documentation.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p>		K 0353	<ol style="list-style-type: none"> 1. The following inspections were initiated: Weekly visual inspection of the dry sprinkler pressure gauges, Monthly visual inspection of the wet sprinkler systems pressure gauges; Monthly visual inspection of the sprinkler system's control values. The dry system trip test and the dry system air leakage test were conducted on 1/30/2023. 2. No other areas of deficiency identified. 3. The Environmental Services Director was inserviced about these requirements. 4. The sprinkler system inspections will be reviewed monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation. 		03/01/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0354 SS=C Bldg. 01	<p>NFPA 101 Sprinkler System - Out of Service Sprinkler System - Out of Service Where the sprinkler system is impaired, the extent and duration of the impairment has been determined, areas or buildings involved are inspected and risks are determined, recommendations are submitted to management or designated representative, and the fire department and other authorities having jurisdiction have been notified. Where the sprinkler system is out of service for more than 10 hours in a 24-hour period, the building or portion of the building affected are evacuated or an approved fire watch is provided until the sprinkler system has been returned to service.</p> <p>18.3.5.1, 19.3.5.1, 9.7.5, 15.5.2 (NFPA 25) Based on record review and interview, the facility failed to provide 1 of 1 correct written policies in the event the automatic sprinkler system has to be placed out-of-service for 10 hours or more in a 24-hour period in accordance with LSC, Section 9.7.5. LSC 9.7.6 requires sprinkler impairment procedures comply with NFPA 25, 2011 Edition, the Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems. NFPA 25, 15.5.2 requires nine procedures that the impairment coordinator shall follow. A.15.5.2 (4) (b) states a fire watch should consist of trained personnel who continuously patrol the affected area. Ready access to fire extinguishers and the ability to promptly notify the fire department are important items to consider. During the patrol of the area, the person should not only be looking for fire, but making sure that the other fire protection features of the building such as egress routes and alarm systems are available and functioning properly. This deficient practice could affect all occupants in the</p>			K 0354	<p>1. The Fire Watch policy was updated to include the necessary contact information.</p> <p>2. No other areas of deficiency identified.</p> <p>3. The Environmental Services Director was inserviced about the requirement.</p> <p>4. The policy will be reviewed monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0363 SS=D Bldg. 01	<p>facility.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 12:13 a.m., the fire watch plan stated to contact the Department of Health but failed to include contacting the Indiana Department of Health via the IDOH Gateway link at https://gateway.isdh.in.gov as the primary method or by the secondary method when the IDOH Gateway is nonoperational by completing the Incident Reporting form and e-mailing it to incidents@isdh.in.gov. Also, the fire watch plan stated to contact the fire department, insurance carrier, facility operator, and mongering company but the space to list phone numbers was blank. Based on interview during the record review, the Administrator acknowledged the fire watch documentation provided stated to contact the department of health but not via the IDOH Gateway link or at the e-mail address listed above and the other contacts were left blank.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Corridor - Doors Corridor - Doors Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas resist the passage of smoke and are made of 1 3/4 inch solid-bonded core wood or other material capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>compartments are only required to resist the passage of smoke. Corridor doors and doors to rooms containing flammable or combustible materials have positive latching hardware. Roller latches are prohibited by CMS regulation. These requirements do not apply to auxiliary spaces that do not contain flammable or combustible material. Clearance between bottom of door and floor covering is not exceeding 1 inch. Powered doors complying with 7.2.1.9 are permissible if provided with a device capable of keeping the door closed when a force of 5 lbf is applied. There is no impediment to the closing of the doors. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies.</p> <p>19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485</p> <p>Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc.</p> <p>Based on observation and interview, the facility failed to ensure 2 of 70 resident room corridor were provided with a means suitable for keeping the door closed, had no impediment to closing, latching, and would resist the passage of smoke. This deficient practice could affect 2 residents in rooms 313 and 401.</p>			K 0363	<p>1. Resident Room doors 313 and 401 were repaired to ensure they latched completely when closed.</p> <p>2. All other resident room doors were checked to ensure proper latching.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0500 SS=E Bldg. 01	Findings include: Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 1:41 p.m. and 2:13 p.m. the corridor door to resident rooms 313 and 401 did not latch into the frame when tested. Based on interview at the time of observation, the Administrator and Environmental Services Director agreed the two corridor doors would not latch into the door frame when tested. The finding was reviewed with the Administrator during the exit conference. 3.1-19(b)			K 0500	3. The Environmental Services Director was inserviced about the requirement. 4. The resident room doors will be reviewed monthly to ensure adherence to the requirement. Audits will be submitted to QAPI committee for review and further recommendation.		03/01/2023
	NFPA 101 Building Services - Other Building Services - Other List in the REMARKS section any LSC Section 18.5 and 19.5 Building Services requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. Based on observation, records review and interview, the facility failed to ensure 3 of 3 fuel fired water heaters had current inspection certificates to ensure the water heaters were in safe operating condition. NFPA 101, Section 19.1.1.3.1 requires all health facilities to be designed constructed, maintained, and operated to minimize the possibility of a fire emergency requiring the evacuation of occupants. The State requires hot water heaters with 100-gallons in capacity to be inspected once every two years. This deficient practice could affect 45 residents in				1. The water heaters were inspected on 2/3/2023 and submitted to DHS. 2. No other deficiencies identified. 3. The Environmental Services Director was inserviced about the requirement. 4. The water heaters will be visually inspected monthly to ensure adherence to the requirement. Audits will be		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0711 SS=C Bldg. 01	<p>three smoke compartments.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 between 12:50 p.m. and 2:00 p.m., the 100-gallon hot water heaters in the 100-hall and 300-hall had an inspection certificate with an expiration date of 11/29/20. Also, the new 100-gallon hot water heater in the main mechanical room had no inspection and has not been registered with the State. Based on records review at 2:50 p.m., no other documentation was available for review to show the three water heaters have been inspected within the last two years. Based on interview at the time of the observation and records review, the Environmental Services Director stated a current inspection for the 3 water heaters could not be found and agreed the posted water heater inspections were past due.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Evacuation and Relocation Plan Evacuation and Relocation Plan There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. Employees are periodically instructed and kept informed with their duties under the plan, and a copy of the plan is readily available with telephone operator or with security. The plan addresses the basic response required of staff per 18/19.7.2.1.2 and provides for all of the fire safety plan components per</p>				submitted to QAPI committee for review and further recommendations.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>18/19.2.2. 18.7.1.1 through 18.7.1.3, 18.7.2.1.2, 18.7.2.2, 18.7.2.3, 19.7.1.1 through 19.7.1.3, 19.7.2.1.2, 19.7.2.2, 19.7.2.3</p> <p>Based on observation, interview, and record review, the facility failed to provide a written plan that addressed all components in 1 of 1 written fire plans in accordance with 19.7.2.2. LSC 19.7.2.2 requires a written health care occupancy fire safety plan that shall provide for the following:</p> <ul style="list-style-type: none"> (1) Use of alarms (2) Transmission of alarm to the fire department (3) Emergency phone call to fire department (4) Response to alarms (5) Isolation of fire (6) Evacuation of immediate area (7) Evacuation of smoke compartment (8) Preparation of floors and building for evacuation (9) Extinguishment of fire <p>This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 12:11 p.m., the facility provided information on evacuation of smoke compartments but did not address the locations of smoke/fire barriers. Based on interview during records review, the Administrator and Environmental Services Director stated no documentation was available to show where all smoke/fire barriers were located.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p>			K 0711	<ul style="list-style-type: none"> 1. The floor plan was updated to identify the location of smoke/fire barriers. 2. No other deficiencies identified. 3. The Environmental Services Director was inserviced about the requirement. 4. The floor plan will be reviewed monthly to ensure accuracy. Audits will be submitted to QAPI committee for review and further recommendations. 		02/20/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0712 SS=F Bldg. 01	<p>NFPA 101 Fire Drills Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 Based on record review and interview, the facility failed to conduct fire drills or verify transmission of signal on each shift for 4 of 4 quarters. LSC 19.7.1.6 states drills shall be conducted quarterly on each shift to familiarize facility personnel (nurses, interns, maintenance engineers, and administrative staff) with the signals and emergency action required under varied conditions. LSC 19.7.1.4 requires fire drills in health care occupancies shall include the transmission of a fire alarm signal and simulation of emergency fire conditions. QSO-20-31 1135 temporary waiver staring on 03/28/20 and ending on 06/07/22 states in lieu of a physical fire drill, a documented orientation training program related to the current fire plan, which considers current facility conditions, is acceptable. The training will instruct employees, including existing, new or temporary employees, on their current duties, life safety procedures and the fire protection devices in their assigned area. This deficient practice affects all staff and residents.</p>			K 0712	<p>1. A fire drill was completed on 3rd shift on 2/17/2023 and transmission of signal was completed on 2/20/2023. 2. No other deficiencies identified. 3. The Environmental Services Director was inserviced about the requirement. 4. The fire drills will be reviewed monthly to ensure accuracy. Audits will be submitted to QAPI committee for review and further recommendations.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0741 SS=E Bldg. 01	<p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 9:41 a.m., the following shifts were missing documentation of a completed fire drill or documented orientation training:</p> <p>a) No fire drill of a third shift drill in the first quarter of 2022.</p> <p>b) No fire drill of a third shift drill in the third quarter of 2022.</p> <p>c) The first shift fire drill for the second quarter of 2022 was missing confirmation of transmission of the fire alarm signal.</p> <p>d) The third shift fire drill for the fourth quarter of 2022 was missing confirmation of transmission of the fire alarm signal.</p> <p>Based on interview at the time of record review, the Environmental Services Director agreed there missing fire drills and two drills did not verify transmission of the fire alarm signal.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b) 3.1-51(c)</p> <p>NFPA 101 Smoking Regulations Smoking Regulations Smoking regulations shall be adopted and shall include not less than the following provisions: (1) Smoking shall be prohibited in any room, ward, or compartment where flammable liquids, combustible gases, or oxygen is used or stored and in any other hazardous location, and such area shall be posted with signs that read NO SMOKING or shall be posted with the international symbol for no</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>smoking.</p> <p>(2) In health care occupancies where smoking is prohibited and signs are prominently placed at all major entrances, secondary signs with language that prohibits smoking shall not be required.</p> <p>(3) Smoking by patients classified as not responsible shall be prohibited.</p> <p>(4) The requirement of 18.7.4(3) shall not apply where the patient is under direct supervision.</p> <p>(5) Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.</p> <p>(6) Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.</p> <p>18.7.4, 19.7.4</p> <p>Based on observation, records review, and interview, the facility failed enforce 1 of 1 non-smoking policies. This deficient practice could affect staff around the service exit.</p> <p>Findings include:</p> <p>Based on observation on 01/30/23 at 9:15 a.m. with the Environmental Services Director at 1:27 p.m., upon arrival to the facility the sides of the building were posted with no smoking sings. Two staff members were observed smoking on the side of the building by the service exit. During the tour of the facility smoking was evident due to there were around 100 cigarette butts on the ground along the building, around and on the generator, and in the landscaping. Based on records review at 11:00, the smoking policy stated smoking is not allowed on the facility's property. Based on interview at the time of observation and records review, the Environmental Services Director stated</p>			K 0741	<p>1. The Smoking Policy was reviewed and revised to identify appropriate smoking areas for employees.</p> <p>2. No other deficiencies identified.</p> <p>3. All employees were inserviced regarding the policy.</p> <p>4. The exterior areas will be reviewed monthly to ensure no evidence of smoking in undesignated areas. Audits will be submitted to QAPI committee for review and further recommendations.</p>		04/02/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0761 SS=F Bldg. 01	<p>the facility is a non-smoking campus and confirmed there was smoking on property due to the cigarette butts on the ground outside the service exit.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>Based on observation, records review, and interview, the facility failed to ensure annual inspection and testing of 7 of 7 fire door assemblies were completed in accordance of LSC 19.1.1.4.1.1 communicating openings in dividing fire barriers required by 19.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.) LSC 8.3.3.1 Openings required to have a fire protection rating by Table 8.3.4.2 shall be protected by approved, listed, labeled fire door assemblies and fire window assemblies and their accompanying hardware, including all frames, closing devices, anchorage, and sills in accordance with the requirements of NFPA 80, Standard for Fire Doors and Other Opening Protectives, except as otherwise specified in this Code. NFPA 80 5.2.1 states fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for inspection by the AHJ. NFPA 80, 5.2.4.1 states fire door assemblies shall be visually inspected from both sides to assess the overall condition of door assembly. NFPA 80, 5.2.4.2 states as a minimum, the following items shall be verified:</p> <p>(1) No open holes or breaks exist in surfaces of</p>			K 0761	<p>1. The Fire Door inspections were completed 2/17/2023.</p> <p>2. No other deficiencies identified.</p> <p>3. The Environmental Services Director was inserviced regarding the policy.</p> <p>4. The fire doors will be reviewed monthly to ensure inspections are maintained. Audits will be submitted to QAPI committee for review and further recommendations.</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>either the door or frame.</p> <p>(2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.</p> <p>(3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.</p> <p>(4) No parts are missing or broken.</p> <p>(5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.</p> <p>(6) The self-closing device is operational; that is, the active door completely closes when operated from the full open position.</p> <p>(7) If a coordinator is installed, the inactive leaf closes before the active leaf.</p> <p>(8) Latching hardware operates and secures the door when it is in the closed position.</p> <p>(9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.</p> <p>(10) No field modifications to the door assembly have been performed that void the label.</p> <p>(11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.</p> <p>This deficient practice could affect all residents.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 10:41 a.m., the annual fire door inspections for the six (6) fire door assemblies in the corridors was past due, the date of the last inspections were on 08/02/21. Also, there was no documentation of an annual inspection for the fire door to the oxygen transfilling room. Based on observation during the tour between 12:30 a.m. and 3:00 p.m., there were six (6) one-and-a-half-hour fire door assemblies in the corridors and a one-and-a-half-hour fire door</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0781 SS=E Bldg. 01	<p>to the oxygen transfilling room. Based on interview at the time of records review and observations, the Environmental Services Director stated the annual fire door inspections were not completed for the seven (7) fire doors within past 12 months.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Portable Space Heaters Portable Space Heaters Portable space heating devices shall be prohibited in all health care occupancies, except, unless used in nonsleeping staff and employee areas where the heating elements do not exceed 212 degrees Fahrenheit (100 degrees Celsius). 18.7.8, 19.7.8 Based on record review, observation, and interview; the facility failed to follow the current space heater policy and develop a portable space heater policy with a maintenance program to ensure the heaters are inspected and temperatures does not exceed 212 degrees for 1 of 1 portable space heaters in staff areas. This deficient practice could affect 10 residents, staff, and visitors in the vicinity of the front admin area.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 12:40 p.m., a portable space heater was in use in the Administrator office. There was no affixed label on the portable space heater ensuring the heater does not exceed 212 degrees. Based on</p>			K 0781	<p>1. The Space Heater Policy was reviewed and revised to maintain compliance with the regulation.</p> <p>2. All areas were reviewed and all space heaters were logged and checked to ensure compliance with the regulation.</p> <p>3. The Environmental Services Director and all Administrative Staff were inserviced regarding the policy.</p> <p>4. The administrative offices will be audited monthly to ensure no unidentified space heaters are in place. All approved space heaters will be checked monthly to ensure they are in proper</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0914 SS=F Bldg. 01	<p>records review at 11:40 a.m., the space heater policy stated space heaters are prohibited in the facility. Based on interview at the time of observation, the Administrator stated the facility does allow space heaters in staff areas, the max temperature of the portable the space heater was unknown, and the space heater policy will be changed to allow space heaters in staff areas.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Electrical Systems - Maintenance and Testing Electrical Systems - Maintenance and Testing Hospital-grade receptacles at patient bed locations and where deep sedation or general anesthesia is administered, are tested after initial installation, replacement or servicing. Additional testing is performed at intervals defined by documented performance data. Receptacles not listed as hospital-grade at these locations are tested at intervals not exceeding 12 months. Line isolation monitors (LIM), if installed, are tested at intervals of less than or equal to 1 month by actuating the LIM test switch per 6.3.2.6.3.6, which activates both visual and audible alarm. For LIM circuits with automated self-testing, this manual test is performed at intervals less than or equal to 12 months. LIM circuits are tested per 6.3.3.3.2 after any repair or renovation to the electric distribution system. Records are maintained of required tests and associated repairs or modifications, containing date, room or area tested, and</p>				working condition. Audits will be submitted to QAPI committee for review and further recommendations.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>results.</p> <p>6.3.4 (NFPA 99)</p> <p>Based on observation, record review and interview, the facility failed to ensure non-hospital grade electrical receptacles at 70 of 70 resident sleeping rooms were tested at least annually. NFPA 99, Health Care Facilities Code 2012 Edition, Section 6.3.4.1.3 states receptacles not listed as hospital-grade, at patient bed locations and in locations where deep sedation or general anesthesia is administered, shall be tested at intervals not exceeding 12 months. Additionally, Section 6.3.3.2, Receptacle Testing in Patient Care Rooms requires the physical integrity of each receptacle shall be confirmed by visual inspection. The continuity of the grounding circuit in each electrical receptacle shall be verified. Correct polarity of the hot and neutral connections in each electrical receptacle shall be confirmed; and retention force of the grounding blade of each electrical receptacle (except locking-type receptacles) shall be not less than 115 grams (4 ounces). This deficient practice could affect all residents.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 11:54 a.m., no documentation was available to show the last time the electrical receptacles in resident sleeping rooms were tested. Based on Observation between 12:00 p.m. and 3:00 p.m., the facility's 70 resident sleeping rooms contained four to eight non-hospital-grade electrical receptacles. Based on interview at the time of the observation and records review, the Environmental Services Director stated all the electrical receptacles in the resident sleeping rooms were not hospital-grade and it was unknown</p>			K 0914	<ol style="list-style-type: none"> 1. Electrical Receptacle testing of all resident rooms were tested. 2. All rooms are at risk for this deficient practice. 3. The Environmental Services Director inserviced on this requirement. 4. The receptacle testing will be audited quarterly x 4 quarters to ensure testing is completed as required. 		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0918 SS=F Bldg. 01	<p>the last time the annual testing was completed.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101</p> <p>Electrical Systems - Essential Electric System Maintenance and Testing</p> <p>The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110.</p> <p>Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE		
	<p>Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>Based on observation, records review, and interview the facility failed to maintain 1 of 1 Natural Gas power generators in accordance with NFPA 99 2012 Chapter 6 which requires monthly testing of the generator serving the emergency electrical system to be in accordance with NFPA 110, the Standard for Emergency and Standby Powers Systems, Chapter 8. This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 11:08 a.m., the following required documentation for the emergency generator was not available for review:</p> <p>a.) Generator exercised under load monthly for a minimum of 30 minutes for February through June of 2022.</p> <p>b.) Generator inspected weekly for February through June of 2022.</p> <p>c.) Battery powered generator task lighting testing for 30 seconds monthly for February through June of 2022.</p> <p>d.) Documenting the cool down time on the monthly load tests for November and December of 2022 and January of 2023.</p> <p>e.) A copy of the natural gas reliability letter from the fuel provider.</p> <p>Based on an interview at the time of record review and observation, the Administrator and Environmental Services Director agreed the aforementioned documentation was not completed or missing.</p>	K 0918	<p>1. Monthly generator load testing completed, weekly inspections completed and continue, Task lighting testing completed, the cool down time has been added to the testing documentation. NIPSCO was contacted and a letter of reliability meeting regulations was requested. Regulation guidance was provided to NIPSCO. An updated Reliability letter was received and has been uploaded.</p> <p>2. Generator testing is currently being completed as required.</p> <p>3. The Environmental Services Director was inserviced on the generator testing requirement.</p> <p>4. The Generator testing will be audited monthly x 6 months to ensure adherence to requirements. Audits will be submitted to QAPI committee for review and further recommendations.</p>		03/13/2023		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0920 SS=E Bldg. 01	<p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Electrical Equipment - Power Cords and Extens Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 Based on observation and interview, the facility failed to ensure 1 of 1 flexible cords and 1 of 1 power strips were not used as a substitute for fixed wiring to provide power equipment with a high current draw. NFPA-70/2011, 400.8 state unless specifically permitted in 400.7 flexible cords</p>			K 0920	<p>1. The extension cord in the DON office was removed. The refrigerator was removed from the power strip and plugged directly into an outlet.</p> <p>2. All areas of the building</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0923 SS=B Bldg. 01	<p>and cables shall not be used for (1) as a substitute for fixed wiring. This deficient practice could affect up to 15 residents in front office area.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 12:51 p.m., a refrigerator (high power draw equipment) was plugged into and supplied power by a power strip in the Medical Records Office. Also, an extension cord was in use and was plugged into a power strip in the DON office. Based on interview at the time of observation, the Environmental Services Director acknowledged an extension cord was in use and a power strip was supplying power to high power draw equipment.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Gas Equipment - Cylinder and Container Storage Gas Equipment - Cylinder and Container Storage Greater than or equal to 3,000 cubic feet Storage locations are designed, constructed, and ventilated in accordance with 5.1.3.3.2 and 5.1.3.3.3. >300 but <3,000 cubic feet Storage locations are outdoors in an enclosure or within an enclosed interior space of non- or limited- combustible construction, with door (or gates outdoors) that can be secured. Oxidizing gases are not stored with flammables, and are separated from combustibles by 20 feet (5 feet if</p>				<p>have the potential to be affected by the deficient practice.</p> <p>3. The Environmental Services Director was inserviced on the requirement.</p> <p>4. The facility will be audited monthly x 6 months to ensure compliance with the regulation. Audits will be submitted to QAPI committee for review and further recommendations.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
	<p>sprinklered) or enclosed in a cabinet of noncombustible construction having a minimum 1/2 hr. fire protection rating. Less than or equal to 300 cubic feet. In a single smoke compartment, individual cylinders available for immediate use in patient care areas with an aggregate volume of less than or equal to 300 cubic feet are not required to be stored in an enclosure. Cylinders must be handled with precautions as specified in 11.6.2.</p> <p>A precautionary sign readable from 5 feet is on each door or gate of a cylinder storage room, where the sign includes the wording as a minimum "CAUTION: OXIDIZING GAS(ES) STORED WITHIN NO SMOKING."</p> <p>Storage is planned so cylinders are used in order of which they are received from the supplier. Empty cylinders are segregated from full cylinders. When facility employs cylinders with integral pressure gauge, a threshold pressure considered empty is established. Empty cylinders are marked to avoid confusion. Cylinders stored in the open are protected from weather.</p> <p>11.3.1, 11.3.2, 11.3.3, 11.3.4, 11.6.5 (NFPA 99)</p> <p>Based on observation and interview, the facility failed to ensure 2 of 2 full oxygen cylinders were separated and marked from empty cylinders to avoid confusion. This deficient practice could affect up to 10 residents in one smoke compartment.</p> <p>Findings include:</p> <p>Based on observation with the Administrator and Environmental Services Director on 01/30/23 at 1:21 p.m., the oxygen storage room contained spots for full and empty oxygen cylinders, but two</p>		K 0923	<p>1. A second rack was acquired and full and empty cylinder tanks were separated.</p> <p>2. The oxygen room has the potential to be affected by this deficient practice.</p> <p>3. All staff have been inserviced on this requirement.</p> <p>4. The oxygen room will be audited monthly x 6 months to ensure compliance with the regulation. Audits will be submitted to QAPI committee for</p>		03/01/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0927 SS=E Bldg. 01	<p>full cylinders were stored in with the empty cylinders in the empty rack. Based on interview at the time of observation, the Environmental Services Director agreed full cylinders were stored with empty cylinders.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Gas Equipment - Transfilling Cylinders Gas Equipment - Transfilling Cylinders Transfilling of oxygen from one cylinder to another is in accordance with CGA P-2.5, Transfilling of High Pressure Gaseous Oxygen Used for Respiration. Transfilling of any gas from one cylinder to another is prohibited in patient care rooms. Transfilling to liquid oxygen containers or to portable containers over 50 psi comply with conditions under 11.5.2.3.1 (NFPA 99). Transfilling to liquid oxygen containers or to portable containers under 50 psi comply with conditions under 11.5.2.3.2 (NFPA 99). 11.5.2.2 (NFPA 99)</p> <p>Based on record review and interview, the facility failed to ensure staff was properly trained on liquid oxygen transfilling procedures based off a safe practices policy in 1 of 1 oxygen transfilling areas. NFPA 99, Health Care Facilities Code, 2012 edition, Section 11.6.1 states administrative authorities of healthcare organizations shall provide policies and procedures for safe practices. Section 11.6.1.3 Policies for enforcement: (1) Regulations for the storage and handling of cylinders and containers of oxygen. Section 11.5.2.3.1 (4) requires that the individual transfilling the container(s) has been properly</p>			K 0927	<p>review and further recommendations.</p> <p>1. A policy has been established regarding the safety requirements of transfilling portable oxygen containers.</p> <p>2. The oxygen room has the potential to be affected by this deficient practice.</p> <p>3. All staff have been inserviced on this requirement.</p> <p>4. Three staff members each month will be interviewed monthly x 6 months to ensure compliance with the regulation. Audits will be</p>		03/01/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155827		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/30/2023	
NAME OF PROVIDER OR SUPPLIER SAGE BLUFF HEALTH & REHAB CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 4180 SAGE BLUFF CROSSING FORT WAYNE, IN 46804			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
	<p>trained in the transfilling procedures. This deficient practice could affect up to 15 residents in one smoke compartment.</p> <p>Findings include:</p> <p>Based on records review with the Administrator and Environmental Services Director on 01/30/23 at 12:00 p.m., there was documentation of how to transfer liquid oxygen into a portable cylinder but there was not a policy on safe practices based off of NFPA 99 Section 11.5.2.3.1. Also, documentation indicating staff have been trained in transfilling procedures was not available for review. Based on interview at the time of record review, the Administrator stated staff were trained in transfilling procedures during orientation but was unable to provide the training documentation or a liquid oxygen transfilling safe practices policy.</p> <p>The finding was reviewed with the Administrator during the exit conference.</p> <p>3.1-19(b)</p>			submitted to QAPI committee for review and further recommendations.			