

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2023  
FORM APPROVED  
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION  |  | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>155654</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____  |                      | (X3) DATE SURVEY COMPLETED<br><br><b>R</b><br><b>09/08/2023</b> |
|---|--|---|---|----------------------|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>ENGLEWOOD HEALTH &amp; REHABILITATION CENTER</b> |  |   | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>2237 ENGLE RD</b><br><b>FORT WAYNE, IN 46809</b>                    |                      |   |
| (X4) ID PREFIX TAG  | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG   | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE |   |
| {E 000}   | Initial Comments<br><br>A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 08/03/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.<br><br>Survey Date: 09/08/23<br><br>Facility Number: 000498<br>Provider Number: 155654<br>AIM Number: 100266110<br><br>At this PSR survey, Englewood Health & Rehabilitation Center was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73.<br><br>The facility has 67 certified beds. At the time of the survey, the census was 50. | {E 000}   |   |                      |   |
| {K 000}   | Quality Review completed on 09/11/23<br>INITIAL COMMENTS<br><br>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 08/03/23 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).<br><br>Survey Date: 09/08/23<br><br>Facility Number: 000498<br>Provider Number: 155654<br>AIM Number: 100266110<br><br>At PSR survey, Englewood Health & Rehabilitation Center was found in compliance  | {K 000}   |   |                      |   |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2023  
FORM APPROVED  
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION  |   | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>155654</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____  |                      | (X3) DATE SURVEY COMPLETED<br><br><b>R</b><br><b>09/08/2023</b> |
|---|---|---|---|----------------------|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>ENGLEWOOD HEALTH &amp; REHABILITATION CENTER</b> |   |   | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>2237 ENGLE RD</b><br><b>FORT WAYNE, IN 46809</b>                    |                      |   |
| (X4) ID PREFIX TAG  | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG   | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE |   |
| {K 000}   | <p>Continued From page 1 with Requirements for Participation Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety From Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in all areas open to the corridor and has hard wired smoke detectors in all resident sleeping rooms. The facility has a capacity of 67 and had a census of 50 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered except for two detached storage buildings.</p> <p>Quality Review completed on 09/11/23</p> | {K 000}   |   |                      |   |