

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/24/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155273</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>06/18/2025</b>	
NAME OF PROVIDER OR SUPPLIER  <b>CYPRESS GROVE REHABILITATION CENTER</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>4255 MEDWELL DR NEWBURGH, IN 47630</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	<p>Initial Comments</p> <p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 06/18/25</p> <p>Facility Number: 000173 Provider Number: 155273 AIM Number: 100290920</p> <p>At this Emergency Preparedness survey, Cypress Grove Rehabilitation Center was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has a capacity of 90 certified beds and had a census of 80 at the time of this visit.</p>			E 000			
K 000	<p>Quality Review completed on 06/23/25</p> <p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 06/18/25</p> <p>Facility Number: 000173 Provider Number: 155273 AIM Number: 100290920</p> <p>At this Life Safety Code survey, Cypress Grove Rehabilitation Center was found in compliance with Requirements for Participation in</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/24/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155273</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>06/18/2025</b>
NAME OF PROVIDER OR SUPPLIER  <b>CYPRESS GROVE REHABILITATION CENTER</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>4255 MEDWELL DR NEWBURGH, IN 47630</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1</p> <p>Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and spaces open to the corridors, plus battery operated smoke alarms in all resident sleeping rooms. The facility has a capacity of 90 and had a census of 80 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered.</p> <p>Quality Review completed on 06/23/25</p>	K 000			