

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/01/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155077		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/30/2024	
NAME OF PROVIDER OR SUPPLIER ENVIVE OF INDIANAPOLIS				STREET ADDRESS, CITY, STATE, ZIP CODE 45 BEACHWAY DR INDIANAPOLIS, IN 46224			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the PSR conducted on 03/27/24 to the Life Safety Code Recertification and State Licensure Survey conducted on 01/30/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 04/30/24</p> <p>Facility Number: 000032 Provider Number: 155077 AIM Number: 100273330</p> <p>At this PSR survey, Envive of Indianapolis was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type III (211) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in all areas open to the corridor and in rooms 11 through 19 in the C Wing. The facility has battery operated smoke detectors in all other resident sleeping rooms. The facility has a capacity of 184 and had a census of 92 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. The facility has four detached buildings providing storage services and one detached building housing an emergency generator which were each not sprinklered.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/01/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155077	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/30/2024
NAME OF PROVIDER OR SUPPLIER ENVIVE OF INDIANAPOLIS			STREET ADDRESS, CITY, STATE, ZIP CODE 45 BEACHWAY DR INDIANAPOLIS, IN 46224		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1	{K 000}			
{K 100}	Quality Review completed on 04/30/24				
SS=E	General Requirements - Other CFR(s): NFPA 101	{K 100}			
	General Requirements - Other List in the REMARKS section any LSC Section 18.1 and 19.1 General Requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. This REQUIREMENT is not met as evidenced by:				
			This tag is temporarily waived from 03/27/24 to 10/31/24.		