

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/28/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15E683	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 11/20/2023
NAME OF PROVIDER OR SUPPLIER MORGANTOWN HEALTH CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 140 W WASHINGTON ST MORGANTOWN, IN 46160		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments A second Post Survey Revisit (PSR) to the PSR conducted on 10/23/23 to the Emergency Preparedness survey conducted on 08/29/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 11/20/23 Facility Number: 000399 Provider Number: 15E683 AIM Number: 100289100 At this PSR survey, Morgantown Health Care was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 39 certified beds. At the time of the survey, the census was 33.	{E 000}			
{K 000}	Quality Review completed on 11/27/23 INITIAL COMMENTS A second Post Survey Revisit (PSR) to the PSR conducted on 10/23/23 to the Life Safety Code Recertification Survey conducted on 08/29/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 11/20/23 Facility Number: 000399 Provider Number: 15E683 AIM Number: 100289100 At this PSR survey, Morgantown Health Care was	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/28/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15E683	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 11/20/2023
NAME OF PROVIDER OR SUPPLIER MORGANTOWN HEALTH CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 140 W WASHINGTON ST MORGANTOWN, IN 46160		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility with a basement was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and all areas open to the corridor. The facility has battery operated smoke detectors installed in all resident sleeping rooms. The facility has a capacity of 39 and had a census of 33 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. The facility has one detached building providing storage services which was not sprinklered.</p> <p>Quality Review completed on 11/27/23</p>	{K 000}			