

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/20/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155705</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/16/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>HERITAGE POINTE OF WARREN</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>801 N HUNTINGTON AVE</b> <b>WARREN, IN 46792</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 04/01/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 05/16/24  Facility Number: 000542 Provider Number: 155705 AIM Number: 100267380  At this PSR survey, Heritage Pointe of Warren was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has a capacity of 119 and had a census of 79 at the time of this survey.	{E 000}			
{K 000}	Quality Review completed on 05/17/24 INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 04/01/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).  Survey Date: 05/16/24  Facility Number: 000542 Provider Number: 155705 AIM Number: 100267380  At this PSR survey, Heritage Pointe of Warren was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/20/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155705</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/16/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>HERITAGE POINTE OF WARREN</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>801 N HUNTINGTON AVE</b> <b>WARREN, IN 46792</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19 Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This two story facility with a walk out lower level was determined to be of Type I (332) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and areas open to the corridors. Hard wired smoke detector were provided in the resident rooms. The facility has a capacity of 119 and had a census of 79 at the time of this survey.</p> <p>All areas providing customary access were sprinklered. All areas providing facility services were sprinklered except two detached barns used for the storage of the facility bus, facility cars, trucks, mowers, snow plows and maintenance supplies and another garage used for the storage of the golf cart.</p> <p>Quality Review completed on 05/17/24</p>	{K 000}			