

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/23/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155479</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>10/19/2023</b>	
NAME OF PROVIDER OR SUPPLIER  <b>KINGSTON CARE CENTER OF FORT WAYNE</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1010 W WASHINGTON CENTER RD</b> <b>FORT WAYNE, IN 46825</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	<p>Initial Comments</p> <p>A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 08/21/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 10/19/23</p> <p>Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040</p> <p>At this PSR survey, Kingston Care Center of Fort Wayne was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has a capacity of 137 and had a census of 100 at the time of this survey.</p>			{E 000}			
{K 000}	<p>Quality Review completed on 10/20/23</p> <p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 08/21/23 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a)</p> <p>Survey Date: 10/19/23</p> <p>Facility Number: 000522 Provider Number: 155479 AIM Number: 100267040</p> <p>At this PSR survey, Kingston Care Center of Fort Wayne was foud in compliance with Requirements for Participation in</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/23/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155479</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>10/19/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>KINGSTON CARE CENTER OF FORT WAYNE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1010 W WASHINGTON CENTER RD</b> <b>FORT WAYNE, IN 46825</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies and with 410 IAC 16.2.</p> <p>The original one-story facility built in 1981 and the 2013 addition was determined to be of Type V (111) construction and was fully sprinklered. The one-story 2007 addition was determined to be Type II (000) and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and hard-wired smoke detector in resident rooms with exception of rooms 401 through 405 which contained battery operated smoke alarms. The building is fully protected by a Bi-fuel (natural gas and diesel) powered 300 kW emergency generator. The facility has a capacity of 137 and had a census of 100 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered. The facility had a detached un-sprinklered storage building providing facility services which was used for the storage of mowing equipment.</p> <p>Quality Review completed on 10/20/23</p>	{K 000}			