

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155001	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/14/2023
NAME OF PROVIDER OR SUPPLIER HOOVERWOOD			STREET ADDRESS, CITY, STATE, ZIP CODE 7001 HOOVER RD INDIANAPOLIS, IN 46260		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments A Post Survey Revisit (PSR) to the PSR conducted on 03/01/23 to the Emergency Preparedness Survey conducted on 01/19/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 04/14/23 Facility Number: 000001 Provider Number: 155001 AIM Number: 100275310 At this PSR survey to the Emergency Preparedness survey, Hooverwood was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 155 certified beds. At the time of the survey, the census was 139.	{E 000}			
{K 000}	Quality Review completed on 04/19/23 INITIAL COMMENTS A Post Survey Revisit (PSR) to the PSR conducted on 03/01/23 to the Life Safety Code Recertification and State Licensure Survey conducted on 01/19/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 04/14/23 Facility Number: 000001 Provider Number: 155001 AIM Number: 100275310	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155001	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/14/2023
NAME OF PROVIDER OR SUPPLIER HOOVERWOOD			STREET ADDRESS, CITY, STATE, ZIP CODE 7001 HOOVER RD INDIANAPOLIS, IN 46260		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 At this PSR survey, Hooverwood was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC). Building 01 was surveyed using Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This two story facility with a basement consists of three portions of one building which was determined to be of Type II (111) construction and was fully sprinklered. Building 01 consists of the memory care wing which is one story, the former kitchen, the basement and the former dining room on the first floor which is now a special events room. The facility has a fire alarm system with smoke detection in the corridor and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system installed in all resident sleeping rooms. The facility has a capacity of 155 and had a census of 139 at the time of this survey. All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered. The facility has no detached buildings providing facility services.	{K 000}			
{K 000}	Quality Review completed on 04/19/23 INITIAL COMMENTS A Post Survey Revisit (PSR) to the PSR conducted on 03/01/23 to the Life Safety Code Recertification and State Licensure Survey conducted on 01/19/23 was conducted by the Indiana Department of Health in accordance with	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155001	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/14/2023
NAME OF PROVIDER OR SUPPLIER HOOVERWOOD			STREET ADDRESS, CITY, STATE, ZIP CODE 7001 HOOVER RD INDIANAPOLIS, IN 46260		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 2 42 CFR 483.90(a).</p> <p>Survey Date: 04/14/23</p> <p>Facility Number: 000001 Provider Number: 155001 AIM Number: 100275310</p> <p>At this PSR survey, Hooverwood was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC). Building 02 and Building 03 were surveyed using Chapter 18, New Health Care Occupancies and 410 IAC 16.2.</p> <p>This two story facility with a basement consists of three portions of one building which was determined to be of Type II (111) construction and was fully sprinklered. Building 02 consists of the 2017 general renovation of all first and second floor resident sleeping room areas not in the memory care wing and the addition of resident sleeping rooms 1238, 1239, 1240 and 1241 on the first floor and resident sleeping rooms 2238, 2239, 2240 and 2241 on the second floor in 2018. Building 03 consists of the renovated first floor main entrance lobby, administrative support offices, conference room, gift shop and beauty shop. The facility has a fire alarm system with smoke detection in the corridor and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system installed in all resident sleeping rooms. The facility has a capacity of 155 and had a census of 139 at the time of this survey.</p> <p>All areas where residents have customary access</p>	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/20/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155001	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 04/14/2023
NAME OF PROVIDER OR SUPPLIER HOOVERWOOD			STREET ADDRESS, CITY, STATE, ZIP CODE 7001 HOOVER RD INDIANAPOLIS, IN 46260		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 3 were sprinklered and all areas providing facility services were sprinklered. The facility has no detached buildings providing facility services. Quality Review completed on 04/19/23	{K 000}			