

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING      -- B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0000  Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 08/13/24</p> <p>Facility Number: 000553 Provider Number: 155660 AIM Number: 100267430</p> <p>At this Emergency Preparedness survey, Pulaski Health Care Center was found in substantial compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 58 certified beds. At the time of the survey, the census was 58.</p> <p>Quality Review completed on 08/19/24</p>			E 0000	<p>The preparation and execution of this Plan of Correction does not constitute admission or agreement, by the provider, of the alleged deficiencies, or the conclusion set forth in the Statement of Deficiencies. The Plan of Correction is prepared and executed solely because it is required by the provisions of federal and state law. This provider maintains that the alleged deficiencies do not individually or collectively jeopardize the health and safety of its residents, nor are they of such character as to limit this provider's capacity to render adequate resident care. Furthermore, the operation and licensure of the long-term care facility and this Plan of Correction in its entirety, constitutes this provider's credible allegation of compliance. Completion dates are provided for procedural purposes to comply with state and federal regulations, and correlate with the most recent contemplated or accomplished corrective action. These dates do not necessarily correspond chronologically to the date the provider is of the opinion that it was in compliance with the requirements of participation. We are respectfully requesting a desk review to clear any and all proposed or implemented</p>		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Thelma Jean Fort

Administrator

08/28/2024

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0013 SS=C Bldg. --	<p>403.748(b), 416.54(b), 418.113(b), 441.184(b), 482.15(b), 483.475(b), 483.73(b), 484.102(b), 485.542(b), 485.625(b), 485.68(b), 485.727(b), 485.920(b), 486.360(b), 491.12(b), 494.62(b)</p> <p>Development of EP Policies and Procedures §403.748(b), §416.54(b), §418.113(b), §441.184(b), §460.84(b), §482.15(b), §483.73(b), §483.475(b), §484.102(b), §485.68(b), §485.542(b), §485.625(b), §485.727(b), §485.920(b), §486.360(b), §491.12(b), §494.62(b).</p> <p>(b) Policies and procedures. [Facilities] must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least every 2 years.</p> <p>*[For LTC facilities at §483.73(b):] Policies and procedures. The LTC facility must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least annually.</p> <p>*Additional Requirements for PACE and ESRD Facilities:</p>				remedies that have been presented to date.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>*[For PACE at §460.84(b):] Policies and procedures. The PACE organization must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must address management of medical and nonmedical emergencies, including, but not limited to: Fire; equipment, power, or water failure; care-related emergencies; and natural disasters likely to threaten the health or safety of the participants, staff, or the public. The policies and procedures must be reviewed and updated at least every 2 years.</p> <p>*[For ESRD Facilities at §494.62(b):] Policies and procedures. The dialysis facility must develop and implement emergency preparedness policies and procedures, based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, and the communication plan at paragraph (c) of this section. The policies and procedures must be reviewed and updated at least every 2 years. These emergencies include, but are not limited to, fire, equipment or power failures, care-related emergencies, water supply interruption, and natural disasters likely to occur in the facility's geographic area.</p> <p>Based on record review and interview, the facility failed to develop and implement emergency preparedness policies and procedures. The policies and procedures must be reviewed and updated at least annually in accordance with 42</p>			E 0013	1. What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice? A: The Emergency Response		08/27/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING      -- B. WING            _____		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>CFR 483.73(b). This deficient practice could affect all residents in the facility.</p> <p>Findings include:</p> <p>Based on review of the facility's Emergency Preparedness Plan on 08/13/24 at 10:13 p.m. with the Maintenance Director, the emergency plan available was not facility specific. The plan given for review had a section that discussed evacuation from the second floor of the facility and this facility is one-story. Based on interview at the time of record review, the Maintenance Director agreed that the facilities Emergency Preparedness Plan discussed evacuation from the second floor of the facility and that the facility was only a one-story building.</p> <p>This item was discussed with both the Maintenance Director and the Administrator at the exit conference.</p>				<p>evacuation policy page 11 was updated on 8/14/24. Removed the verbiage "Do not utilize elevators in case of emergency evacuation."</p> <p>2. How other residents having the potential to be affected by the same alleged deficient practice will be identified and what corrective action(s) will be taken? A: No residents were affected by the alleged deficiency. The policy was updated on 8/14/24.</p> <p>3. What measures will be put into place and what systemic changes will be made to ensure that the alleged deficient practice does not recur? A: Administrator and Maintenance Director reviewed all Emergency Preparedness Policies on 8/14/24 to ensure accuracy. All other policies were accurate and up to date. On 8/27/24 during the monthly QA meeting, provided the QA Committee the information on the updated policy page 11 with the removal of the verbiage "Do not utilize elevators in case of emergency evacuation."</p> <p>4. How the corrective action(s) will be monitored to ensure the alleged deficient practice will not recur; what quality assurance program will be put into place? A: All updates to the Emergency Preparedness policies will be reviewed by both Administrator</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660	X2) MULTIPLE CONSTRUCTION A. BUILDING      -- B. WING            _____		X3) DATE SURVEY COMPLETED 08/13/2024
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0000  Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 08/13/24</p> <p>Facility Number: 000553 Provider Number: 155660 AIM Number: 100267430</p> <p>At this Life Safety Code survey, Pulaski Health Care Center was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire, the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility, consisting of the original building and a later addition was surveyed as one building since both were determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors, spaces open to the corridors, and resident rooms in the northeast wing. All other resident rooms are equipped with</p>	K 0000	<p>and Maintenance Director and will be presented to the Quality Assurance Committee for review and approval.</p> <p>5. By what date the systemic changes will be completed? A: 8/27/24</p> <p>The preparation and execution of this Plan of Correction does not constitute admission or agreement, by the provider, of the alleged deficiencies, or the conclusion set forth in the Statement of Deficiencies. The Plan of Correction is prepared and executed solely because it is required by the provisions of federal and state law. This provider maintains that the alleged deficiencies do not individually or collectively jeopardize the health and safety of its residents, nor are they of such character as to limit this provider's capacity to render adequate resident care. Furthermore, the operation and licensure of the long-term care facility and this Plan of Correction in its entirety, constitutes this provider's credible allegation of compliance. Completion dates are provided for procedural purposes to comply with state and federal regulations, and correlate with the most recent contemplated or</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0345 SS=F Bldg. 01	<p>battery powered single station smoke detectors. The facility has the capacity for 58 and had a census of 58 at the time of this survey.</p> <p>All areas residents have customary access to were sprinklered. The facility also has one detached equipment shed that was unsprinklered.</p> <p>Quality Review completed on 08/19/24</p> <p>NFPA 101 Fire Alarm System - Testing and Maintenance Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 Based on record review and interview, the facility failed to maintain 1 of 1 fire alarm systems in accordance with NFPA 72, National Fire Alarm Code as required by LSC Sections 19.3.4.5.1 and 9.6. NFPA 72, Section 14.3.1 states that unless otherwise permitted by 14.3.2, visual inspections shall be performed in accordance with the schedules in Table 14.3.1, or more often if required by the authority having jurisdiction. Table 14.3.1 states that the following must be visually inspected semi-annually: a. Control unit trouble signals b. Remote annunciators c. Initiating devices (e.g. duct detectors, manual fire alarm boxes, heat detectors, smoke detectors,</p>			K 0345	<p>accomplished corrective action. These dates do not necessarily correspond chronologically to the date the provider is of the opinion that it was in compliance with the requirements of participation. We are respectfully requesting a desk review to clear any and all proposed or implemented remedies that have been presented to date.</p> <p>1. What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice? A: On 8/13/24, Administrator educated Maintenance Director on his responsibilities to ensure all required inspections are completed within the guidance time lines set by ISDH. Maintenance Director expressed his understanding. 8/15/24 Maintenance Director contacted Brenneco and scheduled the required visual inspection of the</p>		08/28/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>etc.) d. Notification appliances e. Magnetic hold-open devices This deficient practice could affect all building occupants.</p> <p>Findings include:</p> <p>Based on review on 08/13/24 at 10:13 p.m. with the Maintenance Director present, documentation could not be provided regarding a visual semi-annual fire alarm system inspection. The most recent testing on the fire alarm was dated 05/22/2024, but there was no documentation of a semi-annual inspection six months prior to that date. Based on interview at the time of record review, the Maintenance Director agreed that as of the time of this survey, a visual semi-annual inspection of the fire-alarm system had not been completed adding that he was unaware of the requirement to have one conducted. This item was discussed with both the Maintenance Director and the Administrator at the exit conference.</p> <p>3.1-19(b)</p>				<p>fire alarm system. Brenneco added the visual inspection to their quarterly inspections to ensure compliance. The next scheduled inspection is 8/28/24.</p> <p>2. How other residents having the potential to be affected by the same alleged deficient practice will be identified and what corrective action(s) will be taken? A: All residents have potential to be affected. The visual inspection of the fire alarm system was added to Brenneco's quarterly inspection schedule to ensure compliance.</p> <p>3. What measures will be put into place and what systemic changes will be made to ensure that the alleged deficient practice does not recur? A: Maintenance Director or designee will utilize the audit tool to record the completion of the visual inspection of the fire alarm system.</p> <p>4. How the corrective action(s) will be monitored to ensure the alleged deficient practice will not recur; what quality assurance program will be put into place? A: Audit results and any corrective action taken will be reported to the Quality Assurance Committee monthly.</p> <p>5. By what date the systemic</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0712 SS=F Bldg. 01	<p>NFPA 101 Fire Drills Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms.</p> <p>19.7.1.4 through 19.7.1.7 Based on record review and interview, the facility failed to conduct quarterly fire drills on each shift for 1 of 4 quarters. LSC 19.7.1.6 requires drills to be conducted quarterly on each shift under varied conditions. This deficient practice affects all staff and residents.</p> <p>Findings include:</p> <p>Based on record review of the "Fire Drill Report" documentation with the Maintenance Director on 08/13/24 at 9:50 a.m., there was no documentation for a fire drill being conducted in the fourth quarter (October, November, and December) of 2023 on the third shift. Based on interview at the time of record review, the Maintenance Director acknowledged the aforementioned missing fire drill.</p> <p>This item was discussed with both the Maintenance Director and the Administrator at the exit conference.</p>			K 0712	<p>changes will be completed? A: 8/28/24</p> <p>1. What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice? A: On 8/13/24, Administrator educated Maintenance Director on the requirement to test the fire alarm system the next morning after each night shift fire drill, when a coded announcement is used. Maintenance Director expressed his understanding and demonstrated the process for Administrator.</p> <p>2. How other residents having the potential to be affected by the same alleged deficient practice will be identified and what corrective action(s) will be taken? A: All residents have potential to be affected. Maintenance Director</p>		08/28/2024



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	3.1-19(b) 3.1-51(c)				<p>and Administrator reviewed the process step by step to ensure Maintenance Director understood that he must complete a test on the fire alarm system the following morning after each night shift fire drill, when a coded announcement is used.</p> <p>3. What measures will be put into place and what systemic changes will be made to ensure that the alleged deficient practice does not recur? A: After each monthly fire drill, Maintenance Director or designee will complete the Fire Drill Report form which will include the information on the testing of the fire alarm system. This report will be reviewed and signed by Administrator to ensure compliance.</p> <p>4. How the corrective action(s) will be monitored to ensure the alleged deficient practice will not recur; what quality assurance program will be put into place? A: Administrator will be reviewing the fire drill form each month and any non-compliance and corrective action taken will be reported to the Quality Assurance Committee monthly. The QA will review and make revisions as warranted on the basis of compliance.</p> <p>5. By what date the systemic changes will be completed?</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0761 SS=F Bldg. 01	<p>NFPA 101 Maintenance, Inspection &amp; Testing - Doors Maintenance, Inspection &amp; Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80) Based on record review, observation and interview, the facility failed to ensure annual inspection and testing of 6 of 6 door assemblies in accordance with LSC 19.1.1.4.1.1. Communicating openings in dividing fire barriers required by 19.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.) LSC 8.3.3.1 Openings required to have a fire protection rating by Table 8.3.4.2 shall be protected by approved, listed, labeled fire door assemblies and fire window assemblies and their accompanying hardware, including all frames, closing devices, anchorage, and sills in accordance with the requirements of NFPA 80, Standard for Fire Doors and Other Opening Protectives, except as otherwise specified in this Code. NFPA 80 5.2.1 states fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for</p>			K 0761	<p>A: 8/28/24</p> <p>1. What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice? A: On 8/13/24, Administrator educated Maintenance Director on the requirement that all fire doors must be inspected annually (within 12 month period) from the date of the prior inspection. Maintenance Director expressed his understanding.</p> <p>2. How other residents having the potential to be affected by the same alleged deficient practice will be identified and what corrective action(s) will be taken? A: All residents have potential to be affected. Maintenance Director</p>		08/28/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>inspection by the AHJ. NFPA 80, 5.2.3.1 states functional testing of fire door and window assemblies shall be performed by individuals with knowledge and understanding of the operating components of the type of door being subject to testing. NFPA 80, 5.2.4.1 states fire door assemblies shall be visually inspected from both sides to assess the overall condition of door assembly.</p> <p>NFPA 80, 5.2.4.2 states as a minimum, the following items shall be verified:</p> <p>(1) No open holes or breaks exist in surfaces of either the door or frame.</p> <p>(2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.</p> <p>(3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.</p> <p>(4) No parts are missing or broken.</p> <p>(5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.</p> <p>(6) The self-closing device is operational; that is, the active door completely closes when operated from the fully open position.</p> <p>(7) If a coordinator is installed, the inactive leaf closes before the active leaf.</p> <p>(8) Latching hardware operates and secures the door when it is in the closed position.</p> <p>(9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.</p> <p>(10) No field modifications to the door assembly have been performed that void the label.</p> <p>(11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.</p> <p>This deficient practice could affect all occupants in the facility.</p>				<p>inspected all fire doors on 8/14/24 and completed the appropriate inspection forms.</p> <p>3. What measures will be put into place and what systemic changes will be made to ensure that the alleged deficient practice does not recur? A: The annual fire door inspection was placed into the TELS system calendar and will automatically populate to the maintenance TO DO list prior to the 1 year timeline. The Administrator receives weekly email confirmation of all compliance and non-compliance from the TELS system.</p> <p>4. How the corrective action(s) will be monitored to ensure the alleged deficient practice will not recur; what quality assurance program will be put into place? A: Administrator reviews all email reports from the TELS system to ensure compliance with inspections. Any non-compliance and corrective action taken will be reported to the Quality Assurance Committee monthly. The QA will review and make revisions as warranted on the basis of compliance.</p> <p>5. By what date the systemic changes will be completed? A: 8/28/24</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0923 SS=E Bldg. 01	<p>Findings include:</p> <p>Based on record review with the Maintenance Director on 08/13/24 at 12:20 a.m., no annual inspection of the fire door assemblies was available for review. Based on observations made during a tour of the facility from 12:01 p.m. to 1:55 p.m., there were a total of six doors located throughout the facility that met the requirement for the annual fire door assemblies inspection. Based on interview at the time of record review, the Maintenance Director stated an annual inspection had not yet been conducted for the fire door assemblies within the facility adding that he would have it completed as soon as possible.</p> <p>This item was discussed with both the Maintenance Director and the Administrator at the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Gas Equipment - Cylinder and Container Storage Gas Equipment - Cylinder and Container Storage Greater than or equal to 3,000 cubic feet Storage locations are designed, constructed, and ventilated in accordance with 5.1.3.3.2 and 5.1.3.3.3. &gt;300 but &lt;3,000 cubic feet Storage locations are outdoors in an enclosure or within an enclosed interior space of non- or limited- combustible construction, with door (or gates outdoors) that can be secured. Oxidizing gases are not stored with flammables, and are separated from combustibles by 20 feet (5 feet if</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>sprinklered) or enclosed in a cabinet of noncombustible construction having a minimum 1/2 hr. fire protection rating. Less than or equal to 300 cubic feet In a single smoke compartment, individual cylinders available for immediate use in patient care areas with an aggregate volume of less than or equal to 300 cubic feet are not required to be stored in an enclosure. Cylinders must be handled with precautions as specified in 11.6.2.</p> <p>A precautionary sign readable from 5 feet is on each door or gate of a cylinder storage room, where the sign includes the wording as a minimum "CAUTION: OXIDIZING GAS(ES) STORED WITHIN NO SMOKING."</p> <p>Storage is planned so cylinders are used in order of which they are received from the supplier. Empty cylinders are segregated from full cylinders. When facility employs cylinders with integral pressure gauge, a threshold pressure considered empty is established. Empty cylinders are marked to avoid confusion. Cylinders stored in the open are protected from weather.</p> <p>11.3.1, 11.3.2, 11.3.3, 11.3.4, 11.6.5 (NFPA 99)</p> <p>Based on observation and interview, the facility failed to ensure 11 of 30 cylinders of nonflammable gases such as oxygen were properly secured from falling. NFPA 99, Health Care Facilities Code, 2012 Edition, Section 11.3.2 states storage for nonflammable gases greater than 8.5 cubic meters (300 cubic feet) but less than 85 cubic meters (3000 cubic feet) shall comply with 11.3.2.1 through 11.3.2.3. NFPA 99, Section 11.3.2.6 states cylinder or container restraints shall comply with 11.6.2.3. Section 11.6.2.3(11) states freestanding cylinders shall be properly chained or supported in a proper cylinder stand or cart.</p>			K 0923	<p>1. What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice? A: The Maintenance Director immediately placed the oxygen canisters into the proper racks and initiated staff education of proper storage of oxygen canisters.</p> <p>2. How other residents having the potential to be affected by the</p>		08/28/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024	
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>This deficient practice could affect as many as 24 residents, 6 staff, and 2 visitors in the facility.</p> <p>Findings include:</p> <p>Based on observations made with the Maintenance Director during a tour of the facility at 12:35 p.m. on 08/13/24, the following was noted:</p> <p>a) there were a total of two 'E' type oxygen cylinders standing upright on the floor of the full oxygen storage tank room.</p> <p>b) there were a total of eleven 'E' type oxygen cylinders standing upright on the floor of the empty oxygen storage tank room.</p> <p>Based on interview at the time of observation, the Maintenance Director acknowledged all of the 'E' type oxygen cylinders in the aforementioned oxygen storage rooms were not properly chained or supported in a proper cylinder stand or cart in both the full and empty oxygen storage rooms in the facility adding that staff knows better that to store these tanks in that manner.</p> <p>This item was discussed with both the Maintenance Director and the Administrator at the exit conference.</p> <p>3.1-19(b)</p>				<p>same alleged deficient practice will be identified and what corrective action(s) will be taken?</p> <p>A: All residents have potential to be affected. The Maintenance Director immediately started the all-staff education on the proper storage of oxygen canisters. Trainings were completed on 8/13/24 and 8/14/24.</p> <p>3. What measures will be put into place and what systemic changes will be made to ensure that the alleged deficient practice does not recur?</p> <p>A: Maintenance Director or designee will monitor the oxygen storage closets daily x 14 days, then weekly x 10 weeks then the inspection will be added to the monthly maintenance checks for permanent monthly audit checks. Maintenance will utilize the audit tool K923 to document inspection results.</p> <p>4. How the corrective action(s) will be monitored to ensure the alleged deficient practice will not recur; what quality assurance program will be put into place?</p> <p>A: Maintenance Director or designee will monitor the oxygen storage closets daily x 14 days, then weekly x 10 weeks then the inspection will be added to the monthly maintenance checks for permanent monthly audit checks to ensure compliance.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/03/2024  
FORM APPROVED  
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155660	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 08/13/2024
NAME OF PROVIDER OR SUPPLIER  PULASKI HEALTH CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP COD 624 E 13TH ST WINAMAC, IN 46996		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
			Maintenance Director or designee will utilize the audit tool K923 to document inspection results. The audit tool will be reviewed by Administrator weekly and any non-compliance and corrective action taken will be reported to the Quality Assurance Committee monthly. The QA will review and make revisions as warranted on the basis of compliance.  5. By what date the systemic changes will be completed? A: 8/28/24		