

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/09/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155242	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 12/08/2021
NAME OF PROVIDER OR SUPPLIER SIGNATURE HEALTHCARE OF MUNCIE			STREET ADDRESS, CITY, STATE, ZIP CODE 4301 N WALNUT ST MUNCIE, IN 47303	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 10/18/21 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).</p> <p>Survey Date: 12/08/21</p> <p>Facility Number: 000146 Provider Number: 155242 AIM Number: 100291200</p> <p>At this PSR survey, Signature Healthcare of Muncie was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire, the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The building was surveyed with Chapter 19 Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinkled. The facility has a fire alarm system with smoke detection in corridors, areas open to the corridor, and battery operated smoke detectors in the resident rooms. The facility has a capacity of 140 and had a census of 105 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinkled and all areas providing facility services were sprinkled.</p> <p>Quality Review completed on 12/08/21</p>	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.