

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/16/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155567	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED C 05/14/2024
NAME OF PROVIDER OR SUPPLIER UNIVERSITY PARK REHABILITATION AND HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 1400 MEDICAL PARK DR FORT WAYNE, IN 46825		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>An Investigation of Complaint Number IN00434430 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Complaint Number IN00434430 was substantiated. No deficiencies related to the allegation were cited.</p> <p>Survey Date: 05/14/24</p> <p>Facility Number: 000459 Provider Number: 155567 AIM Number: 100289700</p> <p>At this investigation complaint survey for a fire, University Park Rehabilitation and Healthcare was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and battery-operated smoke detectors in the resident rooms. The facility has a capacity of 104 and had a census of 62 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinkled. The facility had a garage providing facility services including the storage of</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155567	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED C 05/14/2024
NAME OF PROVIDER OR SUPPLIER UNIVERSITY PARK REHABILITATION AND HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 1400 MEDICAL PARK DR FORT WAYNE, IN 46825		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 maintenance supplies that were not sprinklered. Quality Review completed on 05/15/24	K 000			