

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/17/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155576	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/13/2025
NAME OF PROVIDER OR SUPPLIER WATERS OF HARTFORD CITY SKILLED NURSING FACILITY			STREET ADDRESS, CITY, STATE, ZIP CODE 0548 S 100 W HARTFORD CITY, IN 47348		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 02/13/25 Facility Number: 000289 Provider Number: 155576 AIM Number: 100291289460 At this Emergency Preparedness survey, Waters of Hartford City Skilled Nursing Facility was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has a capacity of 65 and had a census of 39 at the time of this survey.	E 000			
K 000	Quality Review completed on 02/14/25 INITIAL COMMENTS A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 02/13/25 Facility Number: 000289 Provider Number: 155576 AIM Number: 100289460 At this Life Safety Code survey, Waters of Hartford City Skilled Nursing Facility was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/17/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155576	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/13/2025
NAME OF PROVIDER OR SUPPLIER WATERS OF HARTFORD CITY SKILLED NURSING FACILITY			STREET ADDRESS, CITY, STATE, ZIP CODE 0548 S 100 W HARTFORD CITY, IN 47348		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type VIII construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and in the resident sleeping rooms. The facility has a capacity of 65 and had a census of 39 at the time of this survey. All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered. Quality Review completed on 02/14/25	K 000			