

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/15/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155589</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>02/13/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>MILLER'S MERRY MANOR</b>		STREET ADDRESS, CITY, STATE, ZIP CODE  <b>730 SCHOOL ST CULVER, IN 46511</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 000	<p>Initial Comments</p> <p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 02/13/24</p> <p>Facility Number: 000489 Provider Number: 155589 AIM Number: 100291210</p> <p>At this Emergency Preparedness survey, Miller's Merry Manor was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 66 certified beds. At the time of the survey, the census was 52.</p>	E 000		
K 000	<p>Quality Review completed on 02/14/24 INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 02/13/24</p> <p>Facility Number: 000489 Provider Number: 155589 AIM Number: 100291210</p> <p>At this Life Safety Code survey, Miller's Merry Manor was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a),</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/15/2024  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155589</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>02/13/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>MILLER'S MERRY MANOR</b>			STREET ADDRESS, CITY, STATE, ZIP CODE  <b>730 SCHOOL ST CULVER, IN 46511</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original building consisted of the Victory Court, Serenity Court, Grand Court, and common areas. In 2015, a Therapy area and Dining Hall extension were added to the original building. The facility was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one-story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in areas opened to the corridors, and battery-operated smoke detectors in the resident sleeping rooms. The building is fully protected by a 200-kW diesel-powered generator. The facility has a capacity of 66 beds dually certified for Medicare and Medicaid, with a census of 52 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 02/14/24</p>	K 000		