

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155589	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>--</u> B. WING <u> </u>	(X3) DATE SURVEY COMPLETED 01/09/2023
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR		STREET ADDRESS, CITY, STATE, ZIP COD 730 SCHOOL ST CULVER, IN 46511		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 01/09/23</p> <p>Facility Number: 000489 Provider Number: 155589 AIM Number: 100291210</p> <p>At this Emergency Preparedness survey, Miller's Merry Manor was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 66 certified beds. At the time of the survey, the census was 40.</p> <p>Quality Review completed on 01/12/23</p>	E 0000		
K 0000 Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 01/09/23</p> <p>Facility Number: 000489 Provider Number: 155589 AIM Number: 100291210</p> <p>At this Life Safety Code survey, Miller's Merry Manor was found in not compliance with</p>	K 0000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Jason Hill

Administrator

02/03/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155589	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED 01/09/2023
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR			STREET ADDRESS, CITY, STATE, ZIP COD 730 SCHOOL ST CULVER, IN 46511	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
K 0321 SS=E Bldg. 01	<p>Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original building consisted of the Victory Court, Serenity Court, Grand Court, and common areas. In 2015, a Therapy area and Dining Hall extension were added to the original building. The facility was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one-story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in areas opened to the corridors, and battery-operated smoke detectors in the resident sleeping rooms. The building is fully protected by a 200-kW diesel-powered generator. The facility has a capacity of 66 beds dually certified for Medicare and Medicaid, with a census of 40 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 01/12/23</p> <p>NFPA 101 Hazardous Areas - Enclosure Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated</p>			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155589	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED 01/09/2023
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR		STREET ADDRESS, CITY, STATE, ZIP COD 730 SCHOOL ST CULVER, IN 46511		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0345 SS=C Bldg. 01	<p>resident room #412 had been converted to a storage area. This room was approximately 120 square feet in size, contained five bed mattresses, a wooden table, a wooden chair with a cloth covered seat, a wooden three drawer chest, and two 18-inch by 18-inch by 42-inch cardboard boxes containing bed mattresses. The aforementioned storage being kept in the room created a hazardous area, but there was no self-closing device on the door leading out to the corridor. Based on an interview at the time of the observation, the Maintenance Supervisor stated that this room was currently being used for facility storage and he was not aware of the necessity for a self-closing device being needed on hazardous rooms that opened to the corridor.</p> <p>This finding was reviewed with the Maintenance Supervisor at the exit conference on 01/09/23 at 2:25 p.m. only as the facility Administrator was not available at this time.</p> <p>3.1-19(b)</p> <p>NFPA 101 Fire Alarm System - Testing and Maintenance Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available.</p> <p>9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 Based on observation and interview, the facility failed to maintain the fire alarm system to assure that it had accurate time and date information in</p>	K 0345	<p>fill out the LSC audit tool for 12 rooms per week(Attachment A), weekly for 4 weeks and then monthly or until compliance is maintained for 60 days. Any findings will be corrected upon discovery and documented on the QAPI log. The QAPI tracking logs are reviewed monthly by the QAPI committee to ensure ongoing compliance is no less 95%. All systematic changes will be completed by January 27, 2023.</p> <p>K345 It is the policy of Miller's Merry Manor Culver to ensure the</p>	01/27/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155589	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED 01/09/2023
NAME OF PROVIDER OR SUPPLIER MILLER'S MERRY MANOR		STREET ADDRESS, CITY, STATE, ZIP COD 730 SCHOOL ST CULVER, IN 46511		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>accordance with the requirements of NFPA 101-2012 edition, Sections 19.3.4 and 9.6 and NFPA 72 - 2010 edition, Sections 14.1, 14.1.1. This deficient practice could affect all residents, staff, and visitors.</p> <p>Findings include:</p> <p>Based on observation of the fire alarm control panel on 01/09/23 at 1:35 p.m. during a tour of the facility with the Maintenance Supervisor, the time and date on the fire alarm control panel were incorrect. The display on the main fire alarm control panel indicated the date and time to be 03/03/23 at 19:24 hours. Based on interview at the time of observation, the Maintenance Supervisor indicated he was aware of the date and time discrepancy as his vendor has come out to try and correct the date and time on the panel, but as of yet, they have had no luck in doing so.</p> <p>This finding was reviewed with the Maintenance Supervisor at the exit conference on 01/09/23 at 2:25 p.m. only as the facility Administrator was not available at the aforementioned time.</p> <p>3.1-19(b)</p>		<p>fire alarm system is tested and maintained per NFPA guidelines.</p> <p>All residents have the potential to be affected by this practice.</p> <p>A new fire panel has been purchased and will be installed upon arrival. (Attachment 1)</p> <p>To prevent reoccurrence the Administrator or designee will fill out the LSC audit tool, once the new panel is installed(Attachment A), weekly for 4 weeks and then monthly or until compliance is maintained for 60 days. Any findings will be corrected upon discovery and documented on the QAPI log. The QAPI tracking logs are reviewed monthly by the QAPI committee to ensure ongoing compliance is no less 95%.</p> <p>All systematic changes will be completed by 3/15/23.</p>	