

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/09/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155297		(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/07/2024	
NAME OF PROVIDER OR SUPPLIER MILLER'S HEALTH & REHAB BY MILLER'S MERRY MANOR				STREET ADDRESS, CITY, STATE, ZIP CODE 3530 MONROE STREET LA PORTE, IN 46350			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	<p>Initial Comments</p> <p>A Post Survey Revisit (PSR) for the Emergency Preparedness Survey that exited on 06/13/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73</p> <p>Survey Date: 08/07/2024</p> <p>Facility Number: 000194 Provider Number: 155297 AIM Number: 100267790</p> <p>At this Emergency Preparedness PSR, Miller's Health and Rehab by Miller's Merry Manor was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 81 certified beds. Sixty-one beds are dually certified for Medicare and Medicaid, Twenty beds are certified only for Medicare. At the time of the survey, the census was 55.</p> <p>Quality Review completed on 08/08/24</p>			{E 000}			
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/13/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).</p> <p>Survey Date: 08/07/2024</p> <p>Facility Number: 000194 Provider Number: 155297 AIM Number: 100267790</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/09/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155297	(X2) MULTIPLE CONSTRUCTION A. BUILDING 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/07/2024
NAME OF PROVIDER OR SUPPLIER MILLER'S HEALTH & REHAB BY MILLER'S MERRY MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 3530 MONROE STREET LA PORTE, IN 46350		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>At this Life Safety Code PSR, Miller's Health and Rehab by Miller's Merry Manor was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire, and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and in resident rooms. The building is fully protected by a 750 kW diesel-powered generator. The facility has a capacity of 81. Sixty-one beds are dually certified for Medicare and Medicaid, Twenty are certified only for Medicare. The facility had a census of 55 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered and all areas which provide facility services were sprinklered.</p> <p>Quality Review completed on 08/08/24</p>	{K 000}			