

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/26/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/22/2024	
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION				STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/02/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).</p> <p>Survey Date: 02/22/24</p> <p>Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420</p> <p>At this Life Safety Code PSR, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000) construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms. The building is fully protected by a 400 kW diesel powered generator. The facility has a capacity of 157 beds dually certified for Medicare and Medicaid and had a census of 56 at the time of this survey.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/26/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/22/2024
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.	{K 000}			
{K 000}	Quality Review completed on 02/23/24 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/02/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 02/22/24 Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420 At this Life Safety Code PSR, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000) construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms.	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/26/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/22/2024
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 2 The building is fully protected by a 400 kW diesel powered generator. The facility has a capacity of 157 beds dually certified for Medicare and Medicaid and had a census of 56 at the time of this survey. All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.	{K 000}			
{K 000}	Quality Review completed on 02/23/24 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/02/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 02/22/24 Facility Number: 000246 Provider Number: 155355 AIM Number: 100275420 At this Life Safety Code PSR, West Bend Nursing and Rehabilitation was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This facility consists of three connected buildings: Building 01, a two story, fully sprinklered building of Type II (222) construction; Building 02, a one story, fully sprinklered building of Type V (000)	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/26/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155355	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 02/22/2024
NAME OF PROVIDER OR SUPPLIER WEST BEND NURSING AND REHABILITATION			STREET ADDRESS, CITY, STATE, ZIP CODE 4600 W WASHINGTON AVE SOUTH BEND, IN 46619		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 3</p> <p>construction with a partial basement and Building 03, a one story, fully sprinklered building of Type V (111) construction. The facility has a fire alarm system with smoke detection in the corridors, in spaces open to the corridors and battery operated smoke detectors in all resident rooms. The building is fully protected by a 400 kW diesel powered generator. The facility has a capacity of 157 beds dually certified for Medicare and Medicaid and had a census of 56 at the time of this survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 02/23/24</p>	{K 000}			