

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/23/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/18/2024
NAME OF PROVIDER OR SUPPLIER HICKORY CREEK AT CRAWFORDSVILLE			STREET ADDRESS, CITY, STATE, ZIP CODE 817 N WHITLOCK AVE CRAWFORDSVILLE, IN 47933		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 06/11/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 07/18/24 Facility Number: 000533 Provider Number: 155419 AIM Number: 100267230 At this PSR survey, Hickory Creek at Crawfordsville was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73 The facility has 36 certified beds. At the time of the survey, the census was 33.	{E 000}			
{K 000}	Quality Review completed on 07/19/24 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure conducted on 06/11/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 07/18/24 Facility Number: 000533 Provider Number: 155419 AIM Number: 100267230 At this PSR survey, Hickory Creek at Crawfordsville was found in compliance with	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/23/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155419	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/18/2024
NAME OF PROVIDER OR SUPPLIER HICKORY CREEK AT CRAWFORDSVILLE			STREET ADDRESS, CITY, STATE, ZIP CODE 817 N WHITLOCK AVE CRAWFORDSVILLE, IN 47933		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type II (000) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and spaces open to the corridors. Resident rooms were equipped with battery powered smoke detectors. The facility has the capacity for 36 and had a census of 33 at the time of this survey.</p> <p>All areas within the facility where residents have customary access were sprinklered. All areas providing facility services were sprinklered except three detached buildings used for oxygen storage, maintenance, and miscellaneous equipment storage that were unsprinklered.</p> <p>Quality Review completed on 07/19/24</p>	{K 000}			