

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155490	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED 10/03/2024
NAME OF PROVIDER OR SUPPLIER AMBASSADOR HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 705 E MAIN ST CENTERVILLE, IN 47330		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>A Pre-Occupancy Life Safety Code Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 10/03/24</p> <p>Facility Number: 000456 Provider Number: 155490 AIM Number: 100288750</p> <p>At this Pre-Occupancy Life Safety Code survey, Ambassador Healthcare was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>The scope of this project included the relocation of one T18/19 bed from room 206 (going from 2 to 1 bed) to RH02 (going from 1 to 2 beds).</p> <p>This two-story facility with a partial basement consists of four attached buildings. Building 01 is a one-story building consisting of Rooms 101 through 120 and Rooms 1 through 8 in the two-story section of the west wing which has a partial basement. Building 02 is a one-story building consisting of rooms RH1 through RH18. Building 03 consists of Rooms 121 through 135 and is a one-story building with a partial basement. Building IV is a one-story building consisting of Rooms 201 through 220 and Rooms 302 through 313. Each building is fully sprinklered and was determined to be of Type V</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155490	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED 10/03/2024
NAME OF PROVIDER OR SUPPLIER AMBASSADOR HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 705 E MAIN ST CENTERVILLE, IN 47330		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 (111) construction and was surveyed as one building. The facility has a fire alarm system with smoke detection in the corridor, in spaces open to the corridor and on all levels except the partial basement in the west wing of Building 01. The facility has battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 137 and had a census of 93 at the time of this Pre-Occupancy visit. Quality Review completed on 10/07/24	K 000			