

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/20/2025
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155776		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 01/28/2025	
NAME OF PROVIDER OR SUPPLIER SPRINGHILL VILLAGE				STREET ADDRESS, CITY, STATE, ZIP COD 1001 E SPRINGHILL DR TERRE HAUTE, IN 47802			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 01/28/25</p> <p>Facility Number: 012188 Provider Number: 155776 AIM Number: 200958030</p> <p>At this Emergency Preparedness survey, Springhill Village was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 99 certified beds. At the time of the survey, the census was 77.</p> <p>Quality Review conducted on 01/29/25</p>			E 0000	We respectfully request a temporary waiver for K921, please see the attached documentation		
K 0000 Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 01/28/25</p> <p>Facility Number: 012188 Provider Number: 155776 AIM Number: 200958030</p> <p>At this Life Safety Code survey, Springhill Village was found not in compliance with Requirements</p>			K 0000	We respectfully request a temporary waiver for K921, please see the attached documentation		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Emma Abbott

Executive Director

02/19/2025

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/20/2025
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155776		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/28/2025	
NAME OF PROVIDER OR SUPPLIER SPRINGHILL VILLAGE				STREET ADDRESS, CITY, STATE, ZIP COD 1001 E SPRINGHILL DR TERRE HAUTE, IN 47802			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0921 SS=F Bldg. 01	<p>for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>The facility was a one story building determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and spaces open to the corridors. Resident rooms are equipped with battery powered smoke detectors. The facility has the capacity for 99 and had a census of 77 at the time of this survey.</p> <p>All areas with customary access to residents were sprinklered. Two detached buildings used for nursing supply, storage, and maintenance storage were not sprinklered.</p> <p>Quality Review conducted on 01/29/25</p> <p>NFPA 101 Electrical Equipment - Testing and Maintenanc</p> <p>Based on records review, observation, and interview; the facility failed to conduct the required maintenance and maintain complete documentation of inspections for Patient Care Related Electrical Equipment (PCREE). NFPA 99 2012 edition, sections 10.3 and 10.5 states the physical integrity, resistance, leakage current, and touch current tests for fixed and portable PCREE is performed as required in 10.3. Testing intervals are established with policies and protocols. All PCREE used in patient care rooms is tested in accordance with 10.3.5.4 or 10.3.6 before being put into service and after any repair or modification. Any system consisting of several electrical</p>			K 0921	We respectfully request a temporary waiver for K921, please see the attached documentation		05/28/2025

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/20/2025
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155776		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/28/2025	
NAME OF PROVIDER OR SUPPLIER SPRINGHILL VILLAGE				STREET ADDRESS, CITY, STATE, ZIP CODE 1001 E SPRINGHILL DR TERRE HAUTE, IN 47802			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>appliances demonstrates compliance with NFPA 99 as a complete system. Service manuals, instructions, and procedures provided by the manufacturer include information as required by 10.5.3.1.1 and are considered in the development of a program for electrical equipment maintenance. Electrical equipment instructions and maintenance manuals are readily available, and safety labels and condensed operating instructions on the appliance are legible. A record of electrical equipment tests, repairs, and modifications is maintained for a period of time to demonstrate compliance in accordance with the facility's policy. Personnel responsible for the testing, maintenance and use of electrical appliances receive continuous training. This deficient practice affects all residents.</p> <p>The findings include:</p> <p>Based on records review and interview with the Maintenance Director on 01/28/25 between 10:15 a.m. and 3:42 p.m., documentation was available for review to show physical integrity checks completed for electric beds in the facility. No documentation for the complete testing of the Patient Care Related Electrical Equipment (PCREE) in use throughout the facility, as required by section 10.5.6.2 of NFPA 99, Health Care Facilities Code was available at the time of the survey. Observation during the building tour revealed that the facility provided electric beds for all residents. The Maintenance Director stated that PCREE such as oxygen concentrators and other electrical medical equipment was present and in use at the facility either leased and provided by companies or owned by the facility. The Maintenance Director stated that the facility was not aware that the PCREE was required to be tested.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/20/2025
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155776		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 01/28/2025	
NAME OF PROVIDER OR SUPPLIER SPRINGHILL VILLAGE				STREET ADDRESS, CITY, STATE, ZIP COD 1001 E SPRINGHILL DR TERRE HAUTE, IN 47802			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	This finding was reviewed with the Maintenance Director at the exit conference. 3.1-19(b)						