

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/19/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155209		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 08/14/2024	
NAME OF PROVIDER OR SUPPLIER WATERS OF CLIFTY FALLS, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 950 CROSS AVE MADISON, IN 47250			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the survey which exited on 07/09/2024 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 08/14/2024 Facility Number: 000116 Provider Number: 155209 AIM Number: 100266330 At this Life Safety Code survey, The Waters of Clifty Falls was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (000) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridor. The facility has battery operated smoke alarms in all resident sleeping rooms. The facility has a capacity of 138 and had a census of 98 at the time of this visit. All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled. The facility has two detached wooden storage buildings which were not sprinkled. Quality Review completed on 08/16/24			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.