

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155187	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 09/06/2022
NAME OF PROVIDER OR SUPPLIER BRICKYARD HEALTHCARE - PORTAGE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 3175 LANCER ST PORTAGE, IN 46368	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 08/02/22 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 09/06/22</p> <p>Facility Number: 000098 Provider Number: 155187 AIM Number: 100290980</p> <p>At this PSR to the Life Safety Code survey, Brickyard Healthcare - Portage Care Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR 483.90(a), Life Safety from Fire, the 2012 edition of the NFPA (National Fire Protection Association) 101, LSC (Life Safety Code), and 410 IAC 16.2. The building was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>The original building was built in approximately 1978 and the addition, which consisted of 300 Hall, was built in approximately 2005. The entire building was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and battery powered smoke detectors in all resident rooms. The facility is fully protected by a 350 kW diesel emergency generator.</p> <p>The facility has a capacity of 186 dually certified for Medicare and Medicaid, and had a census of 114 at the time of this survey.</p>	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2022
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155187	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 09/06/2022
NAME OF PROVIDER OR SUPPLIER BRICKYARD HEALTHCARE - PORTAGE CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 3175 LANCER ST PORTAGE, IN 46368		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 Quality Review completed on 09/07/22	{K 000}			