

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/08/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155535		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/07/2025	
NAME OF PROVIDER OR SUPPLIER WILLOW CROSSING HEALTH & REHABILITATION CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 3550 CENTRAL AVE COLUMBUS, IN 47203			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments			{E 000}			
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/10/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 05/07/25</p> <p>Facility Number: 000572 Provider Number: 155535 AIM Number: 100267710</p> <p>At this PSR survey, Willow Crossing Health & Rehabilitation Center was found in compliance with Requirements for Participation Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety From Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility consists of two buildings. Building 01, the original building, was determined to be of Type V (111) construction and was fully sprinklered. Building 02, the New Wing addition added to the west end of the original building in 2022, was determined to be of Type V(111) construction and was fully sprinklered. Building 02 consists of new occupational & physical therapy rooms and a 32-bed locked unit in the new 300 Hall. Building 01 was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>Building 01 has a fire alarm system with smoke</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/08/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155535	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/07/2025
NAME OF PROVIDER OR SUPPLIER WILLOW CROSSING HEALTH & REHABILITATION CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 3550 CENTRAL AVE COLUMBUS, IN 47203		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 detection in the corridors, in all areas open to corridor and hard-wired smoke detectors in all resident rooms. The facility has a capacity of 112 and had a census of 99 at the time of the survey. All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.	{K 000}			
{K 000}	Quality Review completed on 05/07/25 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/10/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 05/07/25 Facility Number: 000572 Provider Number: 155535 AIM Number: 100267710 At this PSR survey, Willow Crossing Health & Rehabilitation Center was found in compliance with Requirements for Participation in Medicare, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2. This one story facility consists of two buildings. Building 01, the original building, was determined to be of Type V (111) construction and was fully sprinklered. Building 02, the New Wing addition added to the west end of the original building in	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/08/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155535	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/07/2025
NAME OF PROVIDER OR SUPPLIER WILLOW CROSSING HEALTH & REHABILITATION CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 3550 CENTRAL AVE COLUMBUS, IN 47203		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 2</p> <p>2022, was determined to be of Type V(111) construction and was fully sprinklered. Building 02 consists of new occupational & physical therapy rooms and a 32-bed locked unit in the new 300 Hall. Building 02 was surveyed with Chapter 18, New Health Care Occupancies.</p> <p>Building 02 has a fire alarm system with smoke detection in the corridors and in all areas open to corridor. Building 02 has smoke detectors connected to the building electrical system in the new 300 Hall resident sleeping rooms with battery backup which report to the 300 Hall nurse's station. The facility has a capacity of 112 and had a census of 99 at the time of the survey.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 05/07/25</p>	{K 000}			