

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/27/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155812</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/16/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>WELLBROOKE OF CRAWFORDSVILLE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>517 CONCORD ROAD CRAWFORDSVILLE, IN 47933</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Pre-Occupancy survey to: remove rooms #216 and #217 from bed inventory, convert comprehensive rooms to residential rooms as follows: rooms #210 through #215 and #218 through #227; increase capacity of comprehensive care rooms from one to two beds: 102-108, 110, 112-119, 129 and 131 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 03/14/23 and 03/16/23</p> <p>Facility Number: 013107 Provider Number: 155812 AIM Number: 201279670</p> <p>At this Life Safety Code Pre-Occupancy survey, Wellbrooke of Crawfordsville was found to be in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code, (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, all areas open to the corridors, and all resident rooms with hard wired smoke detectors. The facility has a capacity of 70 and had a census of 51 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/27/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155812</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/16/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>WELLBROOKE OF CRAWFORDSVILLE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>517 CONCORD ROAD</b> <b>CRAWFORDSVILLE, IN 47933</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 Quality Review completed on 03/20/23	K 000			