

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2024
FORM APPROVED
OMB NO. 0938-0391

| | | | | | | | |
|--|---|--|--|--|--|--|----------------------------|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155718 | | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 06/11/2024 | |
| NAME OF PROVIDER OR SUPPLIER NORTHVIEW HEALTH AND LIVING | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 1235 W CROSS ST ANDERSON, IN 46011 | | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | | (X5) COMPLETION DATE |
| {K 000} | INITIAL COMMENTS A Post Survey Revisit (PSR) to the PSR conducted on 05/20/24 to the Life Safety Code Recertification and State Licensure Survey conducted on 04/09/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 06/11/24 Facility Number: 000562 Provider Number: 155718 AIM Number: 100267150 At this PSR Life Safety Code survey, Northview Health and Living was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one-story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, battery operated smoke detectors in all resident rooms in the building. The facility has a capacity of 101 and had a census of 64 at the time of this PSR visit. All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered except for two detached garages used for storage which were not sprinklered. | | | {K 000} | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

| | | | | | |
|--|--|--|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155718 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 06/11/2024 |
| NAME OF PROVIDER OR SUPPLIER NORTHVIEW HEALTH AND LIVING | | | STREET ADDRESS, CITY, STATE, ZIP CODE 1235 W CROSS ST ANDERSON, IN 46011 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE | |
| {K 000} | Continued From page 1 Quality Review completed on 06/11/24 | {K 000} | | | |