

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155792	(X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____	(X3) DATE SURVEY COMPLETED 10/30/2024
NAME OF PROVIDER OR SUPPLIER  COUNTRYSIDE MEADOWS		STREET ADDRESS, CITY, STATE, ZIP COD 762 N DAN JONES RD AVON, IN 46123		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000  Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 10/30/24</p> <p>Facility Number: 012534 Provider Number: 155792 AIM Number: 201028420</p> <p>At this Emergency Preparedness survey, Countryside Meadows was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73</p> <p>The facility has 171 certified beds. At the time of the survey, the census was 130.</p> <p>Quality Review completed on 11/01/24</p>	E 0000	<p>Ms. Brenda Buroker Director of Long Term Care 2 North Meridian St. Indianapolis, IN 46204</p> <p>Re: Survey Event ID O26X21</p> <p>Dear Ms. Buroker:</p> <p>Please find attached my Plan of Correction for the deficiencies cited during this Life Safety Survey. I am respectfully requesting paper compliance.</p> <p>If you have any questions, please feel free to contact me.</p> <p>Sincerely,</p> <p>Karsen Rauch, HFA Administrator Countryside Meadows – Avon, IN.</p>	
K 0000  Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 10/30/24</p> <p>Facility Number: 012534 Provider Number: 155792</p>	K 0000	<p>Ms. Brenda Buroker Director of Long Term Care 2 North Meridian St. Indianapolis, IN 46204</p> <p>Re: Survey Event ID O26X21</p> <p>Dear Ms. Buroker:</p>	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Karsen Rauch

Executive Director, HFA

11/13/2024

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155792	(X2) MULTIPLE CONSTRUCTION A. BUILDING B. WING  01	(X3) DATE SURVEY COMPLETED 10/30/2024
NAME OF PROVIDER OR SUPPLIER  COUNTRYSIDE MEADOWS		STREET ADDRESS, CITY, STATE, ZIP COD 762 N DAN JONES RD AVON, IN 46123		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0324 SS=E Bldg. 01	<p>AIM Number: 201028420</p> <p>At this Life Safety Code survey, Countryside Meadows was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and is fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system in all resident sleeping rooms. The facility has a capacity of 171 and had a census of 130 at the time of this visit.</p> <p>All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p> <p>Quality Review completed on 11/01/24</p> <p>NFPA 101 Cooking Facilities</p> <p>Based on observation and interview, the facility failed to provide an approved method for returning cooking appliances to where they were when the kitchen hood extinguishing equipment was designed and installed for 1 of 1 kitchen hood extinguishing system. NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations Section 2011 Edition Section 12.1.2.2, states cooking appliances requiring protection shall not be moved, modified, or rearranged without prior re-evaluation of the</p>	K 0324	<p>Please find attached my Plan of Correction for the deficiencies cited during this Life Safety Survey. I am respectfully requesting paper compliance.</p> <p>If you have any questions, please feel free to contact me.</p> <p>Sincerely,</p> <p>Karsen Rauch, HFA Administrator Countryside Meadows – Avon, IN.</p>	11/13/2024

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER <b>155792</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED <b>10/30/2024</b>	
NAME OF PROVIDER OR SUPPLIER <b>COUNTRYSIDE MEADOWS</b>			STREET ADDRESS, CITY, STATE, ZIP COD <b>762 N DAN JONES RD AVON, IN 46123</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>fire-extinguishing system by the system installer or servicing agent, unless otherwise allowed by the design of the fire extinguishing system. Section 12.1.2.3 states the fire-extinguishing system shall not require reevaluation where the cooking appliances are moved for the purposes of maintenance and cleaning, provided the appliances are returned to approved design location prior to cooking operations, and any disconnected fire-extinguishing system nozzles attached to the appliances are reconnected in accordance with the manufacturer's listed design manual. Section 12.1.2.3.1 states an approved method shall be provided that will ensure that the appliance is returned to an approved design location. The deficient practice could affect as many as residents and staff.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Director of Maintenance on 10/30/24 at 1:44 p.m., the two (2) burner flat grill which was located on the cooking line under the hood in the kitchen was not provided with an approved method that would ensure that the appliance was returned to an approved design location after it had been moved for maintenance and cleaning. Based on interview at the time of the observation, the Maintenance Director stated that he was not aware an approved method should be provided to ensure that the appliance was returned to an approved design location after maintenance or cleaning and that he would order a "wheel chalk" and have it installed on the kitchen floor as soon as possible.</p> <p>This item was discussed with the Administrator and the Director of Maintenance at the exit conference on 10/30/24.</p>			<p><b>residents having the potential to be affected by the same deficient practice and what corrective action will be taken?</b> All residents have the potential to be affected by the alleged deficient practice.</p> <p><b>What measures will be put into place or what systemic changes you will make to ensure that the deficient practice does not recur?</b> Education was provided to the maintenance director and executive director during exit conference. Once the wheel chalks come in, they will be installed immediately.</p> <p><b>How the corrective action (s) will be monitored to ensure the deficient practice will not recur, i.e., what quality assurance program will be put into place?</b> The Maintenance Director will check the wheel chalks regularly to make sure they are still intact.</p> <p>He will review in bi-monthly QAPI as well to ensure continued compliance and quality assurance.</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155792	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED 10/30/2024
NAME OF PROVIDER OR SUPPLIER  COUNTRYSIDE MEADOWS		STREET ADDRESS, CITY, STATE, ZIP COD 762 N DAN JONES RD AVON, IN 46123		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0711 SS=C Bldg. 01	<p>3.1-19(b)</p> <p>NFPA 101 Evacuation and Relocation Plan</p> <p>Based on record review and interview, the facility failed to provide a complete facility specific written fire safety plan for the protection of 130 of 130 residents to accurately address all life safety systems, plus a system addressing all items required by NFPA 101, 2012 edition, Section 19.7.2.2. LSC 4.8.2.1(3) requires evacuation procedures appropriate to the building, its occupancy, emergencies and hazards. LSC 19.7.2.2 requires a written health care occupancy fire safety plan that shall provide for the following:</p> <ul style="list-style-type: none"> <li>(1) Use of alarms</li> <li>(2) Transmission of alarm to fire department</li> <li>(3) Emergency phone call to fire department</li> <li>(4) Response to alarms</li> <li>(5) Isolation of fire</li> <li>(6) Evacuation of immediate area</li> <li>(7) Evacuation of smoke compartment</li> <li>(8) Preparation of floors and building for evacuation</li> <li>(9) Extinguishment of fire</li> </ul> <p>This deficient practice could affect all occupants in the event of an emergency.</p> <p>Findings include:</p> <p>Based on a review of the fire plan within the Emergency Preparedness Binder entitled "Emergency Preparedness Program" on 10/30/24 at 9:21 a.m. with the Director of Maintenance present, the available fire plan was a generic fire plan and was not building specific. The aforementioned plan in: Section C - Emergency Job Task: Fire under area G stated "Procedures for</p>	K 0711	<p>Plan of Correction <b>K711 Evacuation and Relocation Plan</b></p> <p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice?</b></p> <p>·Upon notification of deficiency the passage was taken out of the emergency preparedness binder referring to "battery powered smoke detectors".</p> <p>·Please see attached photo.</p> <p><b>How will you identify other residents having the potential to be affected by the same deficient practice and what corrective action will be taken?</b></p> <p>·All residents/staff have the potential to be affected by the alleged deficient practice.</p> <p><b>What measures will be put into place or what systemic changes you will make to ensure that the deficient practice does not recur?</b></p>	11/13/2024

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER  155792	(X2) MULTIPLE CONSTRUCTION A. BUILDING <u>01</u> B. WING _____	(X3) DATE SURVEY COMPLETED 10/30/2024
NAME OF PROVIDER OR SUPPLIER  COUNTRYSIDE MEADOWS			STREET ADDRESS, CITY, STATE, ZIP COD  762 N DAN JONES RD AVON, IN 46123	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
	<p>staff in response to Battery-Powered Smoke Detectors, yet all smoke detectors located within the resident rooms were hardwired. This was acknowledged by the Director of Maintenance at the time of record review.</p> <p>This item was discussed with the Administrator and the Director of Maintenance at the exit conference on 10/30/24.</p> <p>3.1-19(b)</p>			<ul style="list-style-type: none"> <li>·Education was provided to the maintenance director and executive director during exit conference.</li> <li>·The unnecessary and inaccurate part of our plan was removed, as it was no longer relevant.</li> </ul> <p><b>How the corrective action (s) will be monitored to ensure the deficient practice will not recur, i.e., what quality assurance program will be put into place?</b></p> <p>The Maintenance Director will make sure to review the plan and endure that the passage isn't added back.</p> <p>The Maintenance Director will review in bi-monthly QAPI as well to ensure continued compliance and quality assurance.</p>